

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/2013/w2/879

Dated: 06/08/2013


FIRE SAFETY CERTIFICATE

Certified that the **J.N.M International School** at D-10, Hari Enclave, Aman Vihar, Dlehi-110086, is comprised of **Ground + One upper floors** owned / occupied by **Sultan Singh Memorial Educational Society**, has already been issued Fire Safety Certificate **vide letter No.F6/DFS/MS/2010/1721 dated 11.06.2010**. The premises was re-inspected by the officer concerned of Fire Service on **17.08.2013** in presence of **Sh. Anil Bhalla (Principal)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of **circular issued by Director of Education, Govt. of NCT of Delhi vide letter No. 262-362 dated 17.01.2005** and that the building / premise is fit for occupancy class **Educational (Group-B)** with effect from **06/08/2013** for a period of **three years** subject to compliance of the conditions mentioned below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

Issued on 06/08/13 **at New Delhi by.**


(SANTOKH SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Phone:-23414250

E-mail: cfowz.dlfire@nic.in

Copy to :-

1. Sh. Anil Bhalla (Principal), J.N.M International School, D-10, Hari Enclave, Aman Vihar, Dlehi-110086.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.

Plot Area = 3000 yard² 1/5 Total class Rooms = (12+2) G+1
 Covered Area = 1800 yard² Students =

INSPECTION REPORT

1. Name & address of the building: JNM International School
D-10, Hari Enclave, Aman Vihar, ND-86
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : Letter No F-6/DFS/MS/2010/1721 / dated 11.6.2010
5. Fire Safety directives Letter No. : Director of Education circ. dated 17.1.05
6. Date of inspection : 17/08/2013
7. Name of the Inspecting Officer : A.K. Jaiswal
8. Name and designation of Officer
 from the building side : Anil Shalla (Principal)
9. Year of Construction : 2009
10. Applicant's letter No. : JNMIS/ESC/FO/1/2013 dt 19/7/13

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL / DDE cir. Requirements ^{17.1.05}	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<u>Accessible</u> <u>Accessible</u>	<u>Provided</u> <u>Provided</u>	<u>MR</u> <u>MR</u>
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<u>2</u> <u>NA</u>	<u>2</u> <u>NA</u>	<u>MR</u> <u>NA</u>
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<u>1.50 Mtr.</u> <u>NA</u>	<u>MR (1.55)</u> <u>NA</u>	<u>MR</u> <u>NA</u>
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 			NR
	d. No of continuous staircase to terrace	<u>1</u>	<u>1</u>	<u>MR</u>
	e. Width Of Corridor	<u>1.50 Mtr.</u>	<u>1.50 Mtr.</u>	<u>MR</u>
	f. Door Size	<u>1.00 Mtr.</u>	<u>1.00 Mtr.</u>	<u>MR</u>

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	7 ABC/CO ₂ ISI marked	Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	1 30 Mtr. 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detector • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 			

1. Internal Hydrants			
<ul style="list-style-type: none"> • Size of riser/down- comer • Number of hydrants per floor • Hose Box 			
	NR		
12. Yard Hydrants			
<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 			
	NR		
13. Pumping Arrangements			
<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 			
	NR		
	220 lpm	Provided	MR
	40 MH	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
14. Captive water Storage for fire fighting			
<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NR	NR	NR
	NR	NR	NR
	Not Required	Provided	MR
	Required	Provided	MR
	2500 lts	3000 lts	MR

15	Exit Signage		NR	
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft			
	➤ Pressurization of lift lobby			
	➤ Communication in lift Car		NR	
	➤ Fireman's Grounding Switch			
	➤ Lift Signage			
17.	Standby power supply		NR	
18.	Refuge Area		NR	
	➤ Total area			
	➤ Location		NR	
19.	Fire control room			
	➤ Detector system panel			
	➤ Flow Switch Panel			
	➤ PA System Panel		NR	
	➤ Batter backup			
	➤ Building Floor Plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Not any fire risk (Special) seen		


The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

.....

(Large blue scribbles)

M/g



Ak Jaiswal
17/8/13

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

A.K. (JAISWAL)

Name

Designation

ADO/(JWA)

Designation