

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/2013/W2/882

Dated: 06/08/2013

FIRE SAFETY CERTIFICATE

Certified that the **St. Maxico Public School** at A-559-560 Budh Vihar, Phase-II, Shyam Colony, New Dlehi-110086, comprised of **Ground floor only** owned / occupied by **Goswami Sarswati Devi Samaj Kalyan Society**, has already been issued Fire Safety Certificate **vide letter No.F6/DFS/MS/2009/1256 dated 08.07.2009** The premises was re-inspected by the officer concerned of Fire Service on **17.08.2013** in presence of **Sh. Santosh Bharti (Owner)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of **circular issued by Director of Education, Govt. of NCT of Delhi vide letter No. 262-362 dated 17.01.2005** and that the building / premise is fit for occupancy class **Educational (Group-B)** with effect from 06/08/2013 for a period of **three years** subject to compliance of the conditions mentioned below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

Issued on 06/08/13 at New Delhi by.


(SANTOKH SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Phone:-23414250

E-mail: cfowz.dlfire@nic.in

Copy to :-

1. Sh. Santosh Bharti (Owner), St. Maxico Public School, A-559-560 Budh Vihar, Phase-II, Shyam Colony, New Dlehi-110086.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.

Plot Area = 200 yard² N/3
 Covered Area = 180 yard²

G.F only

INSPECTION REPORT

1. Name & address of the building: St. Maxico Public School
A-559-560, Shyam Colony
Balshikhar Phase II, Delhi-41
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : Letter No F.6/DFS/MS/2009/1256/8.7.2009
5. Fire Safety directives Letter No. : F.6/DFS/MS/2009/1256/8/7/2009
DOE 17/8/13
6. Date of inspection : 17/8/13
7. Name of the Inspecting Officer : A.K. Jaiswal
8. Name and designation of Officer
 from the building side : Santosh Bharti / (owner)
9. Year of Construction : —
10. Applicant's letter No. : —

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL / DOE etc. Requirements	Provided at site	Remarks MR/NMR
1.	Access of building	17.1.05		
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road			
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door			
	• Pressurization		NR	
	d. No of continuous staircase to terrace		N/A	
	e. Width Of Corridor	old case	old case	old case
	f. Door Size	old case	old case	old case

N/A

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			NR
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour		NR
		12 a/c per hour		
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	2 ABC/CO ₂ ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 			NR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			NR
8.	MOEFA			NR
9.	Public Address System			NR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 			NR

11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down- comer • Number of hydrants per floor • Hose Box 			
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 			
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 			
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage			
16.	Provision of Lifts			

NR

NR


NR

NR

NR

N/6

	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 			
17.	Standby power supply			NR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 			NR
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Batter backup ➤ Building Floor Plans 			NR
20.	Special Fire Protection Systems for Protection of special Risks, if any;			INA



The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue ~~shortcomings as noted at serial numbers~~

Signature of the Inspecting Officer
AK Jaiswal
17.8.13

Signature of the Inspecting Officer

Name (A.K. JAISWAL)

Name

Designation ADO/(JWP)

Designation