

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/School/2013/W2/898 Dated: 10/09/2013

FIRE SAFETY CERTIFICATE

Certified that the Rao Mahar Chand Saraswati Vidya Mandir, Guru Nanak nagar, Delhi-110042 is comprised of Ground floor only owned/occupied by Rao Mahar Chand Saraswati Vidya Mandir has already been issued fire safety certificate vide letter no. F-6/DFS/MS/2008/2456 dated 27/08/2008. The premises was re-inspected by the officer from this department on dated 22/08/2013 in the presence of Mrs. Renu Vashistha and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have there fore deemed complied with the requirements of circular issued by Director of Education letter dated 17/01/2005 and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 10/09/2013 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 10/09/13 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. Rao Mahar Chand Saraswati Vidya Mandir, Guru Nanak nagar, Delhi-110042
2. Director of Education, Old Sectt. Delhi for information



S/N

Renewal case

INSPECTION REPORT

1. Name & address of the building Rao Mehar Chand Saraswati Vidya Mandir, Guru Nanak
2. Type of Occupancy Educational
3. Type of Case New Case / Renewal
4. Details of previous NOC F-6/DPs/MB/08/2456 dated
5. Fire Safety directives letter No Circular, Dir. of Edn-17/8/2005
6. Date of inspection 22-8-2013
7. Name of the Inspecting Officers : D.O. - SHYAM LAL
8. Name and designation of officers
from the building side Mrs. Renu Vashistha (Principal)
9. Year of Construction 1994, (Ground only.)
10. Applicant's letter No. 311 dated 7-8-2013

	Minimum Standards on fire prevention and fire safety U/R 33	<u>Circulars Dir. of Edn. NBC Requirement 4/3/2011 17-3-05</u>	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessible</u>	<u>6 m</u>	<u>M/R</u>
	• Gate width	<u>—do—</u>	<u>4.80 m</u>	<u>M/R</u>
	• Width of internal road	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases		<u>N/A</u>	
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	<u>1 m</u>	<u>4.12 m [one door 3 room 0.5 room with two doors less than 115 standard in inches]</u>	<u>M/R</u>
3	Compartmentation.			
	• Fire check door		<u>N/A</u>	<u>1</u>

FIN

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 		NIR	
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour	NIR	
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	05 ABC(CO2(GSM)) ISI marked	06 ABC Provided	NIR NIR NIR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m 5 mm	NIR	
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 		NIR	
8	MOEFA		NIR	
9	Public Address System.		NIR	
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 		NIR	
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 		NIR	
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 		NIR	

13	Pumping Arrangements.				
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pum 			NIR	
14	Captive Water Storage for fire fighting.				
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			NIR	
15	Exit Signage.				
16	Provision of Lifts.				
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			NIR	NIA
17	Standby power supply				
18	Refuge Area.				
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			NIR	NIA
19	Fire Control Room				
	<ul style="list-style-type: none"> • Detector System Panel 			NIR	

9/N



- Flow Switch Panel
- PA System Panel
- Batter backup
- Building Floor Plans

NIR

20	Special Fire Protection Systems for Protection of special Risks, if any:	—	NIL	—
----	--	---	-----	---

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer D.O.
NW

Name

Designation

Guip
27/8/13
20(NW)

Signature of the Inspecting Officer Shyam Lal 23/8/2013

Name (SHYAM LAL)

Designation D.O.