

M

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/School/2013/w2/897

Dated: 10/09/2013

FIRE SAFETY CERTIFICATE

Certified that the **Shivam Model Public School, E-2, Prem Nagar-III, Kirari Suleman Nagar, Delhi-110086** is comprised of **Ground Floor Only** owned/occupied by **Shivam Model Public School,** has already been issued fire safety certificate **vide letter no. F-6/DFS/MS/2009 / 230 dated 27/01/2009.** The premises was re-inspected by the officer from this department on dated 25/07/2013 in the presence of **MR. Pardeep Kumar, (Manager)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have there fore deemed complied with the requirements of **circular issued by Director of Education letter dated 17/01/2005** and the building / premise is fit for occupancy of **Group Class B (Educational)** with effect from **10 / 09 / 2013** for a period of **three years,** subject to compliance of the conditions mentioned below:


Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 10/09/13 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Shivam Model Public School, E-2, Prem Nagar-III, Kirari Suleman Nagar, Delhi-110086
 2. The Director of Education, Old Secretariat, Delhi
- 

G. Floor

INSPECTION REPORT

1. Name & address of the building: SHIVAM MODEL PUBLIC SCHOOL, E-2, PREM NAGAR - III, KIRARI SOLEMAN NAGAR, DELHI-86
2. Type of Occupancy: EDUCATIONAL
3. Type of Case: New Case / Renewal
4. Details of previous NOC: F-6/DFS/MS/2009/203 dt 27-01-09.
5. Fire Safety directives letter No: Circular of Director of Education
6. Date of inspection: 25-7-13.
7. Name of the Inspecting Officers: N.P. Sharma Asstt. Div. officer
8. Name and designation of officers from the building side: Hardeep Kumar Manager
9. Year of Construction: 1998
10. Applicant's letter No: SMPs/04/13 dt 23-4-13

P.A - 3100 Sqft, C.A. 750 Sqft. Noh S-428, Noh T-14, Noh CR-11. Noh's

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>Accessible</p> <p>Accessible</p> <p>—</p>	<p>Accessible</p> <p>Accessible</p> <p>—</p>	<p>MR</p> <p>MR</p> <p>—</p>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases <ul style="list-style-type: none"> • Upper Floors • Basements b. Width of staircases <ul style="list-style-type: none"> • Upper Floors • Basements c. Protection of exits <ul style="list-style-type: none"> • Fire check door • Pressurization e. No. of continuous staircases to terrace g. Width of Corridor h. Door Size	N/A		
		100 cm	100 cm.	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain 	N/A		

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	02	04	MR
		ISI marked	ABC	MR
			P	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m	N/A	
		5 mm		
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A		
8	MOEFA	—	—	—
9	Public Address System.	—	—	—
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	N/A		
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A		
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A		
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump 	N/A		

	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply			
18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer ^{ADDTA} 31-7-13

Name N. P. SHARMA

Designation Assst. Div. offcr

Signature of the Inspecting Officer

Name

Designation