

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/school/2013/W2/9/15 Dated: 13/09/2013

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Bal Vidyalaya No. – 1, Shakurpur, Delhi consists two blocks comprised of Ground plus upper three floors & Ground + one upper floor owned/occupied by Govt. Sarvodaya Bal Vidyalaya No. – 1, Shakurpur, Delhi have complied with the fire prevention and fire safety requirements in accordance with, the Circular No F.16/ Estate/ CC/ Fire Safety/2011/3298 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 18/08/2013 in the presence of Sh. S. K. Sharma (Vice-Principal) and that the building / premises is fit for occupancy of **Educational** building with effect from 13/09/2013 for a period of **three years**, compliance of following conditions.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupied shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 13/09/13 at New Delhi


13/9
(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Vice- Principal, Govt. Sarvodaya Bal Vidyalaya No. – 1, Shalkurpur, Delhi – 110034.
2. The Director of Education, Govt. of NCT of Delhi.

Total Blocks = 02 - 1/1 -
 Block-01 = Ground + Three upper floors
 Block 02 = Ground + One upper floor

INSPECTION REPORT

1. Name & address of the building : Govt. Samodaya Bal Vidyalaya, No-1, Shakurpur Delhi-34
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. _____ Dated: _____
5. Fire Safety directives letter No : D.O.E. Circular dt. 01/3/2011 / NBC -17
6. Date of inspection : 18/08/2013
7. Name of the Inspecting Officers : D.O.S.K.DUG
8. Name and designation of officers from the building side : Sh. S.K. Sharma, Vice-Principal
9. Year of Construction : 1958
10. Applicant's letter No. : Nil dt. 25/7/2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement / D.O.E Circular dt. 01/3/2011	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	— de —	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2 in each block	2 in each block	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 mtr	1) 1.52 mtr, 1.36 mtr 2) 1.46 mtr, 1.46 mtr	MR MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	One	Two provided	MR
	g. Width of Corridor	1.5 mtr	Provided	MR
	h. Door Size	1.0 mtr	2X 1.0 mtr - Provided (with door frame)	MR

c. N/A.

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		N/A	
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	NA open to sky	NA NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types ABC-Step. CO₂ 2-Step. • IS marking 	25 ISI marked	32 (Twenty two) Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	Two 30 m 5 mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		N/A	
8	MOEFA	NA	NA	NA
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 		N/A	
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NA	100 mm	MR

N/A

	<ul style="list-style-type: none"> Number of hydrants per floor Hose Box 	NA	Two on each floor	MR
		NA	- do -	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 		N/A	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
			N/A	
		450 LPM	450 LPM	MR
		40 mtr.	40 Mtr.	MR
		Required	Provided	MR
		Required	Provided	MR
		-	-	-
		-	-	-
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 			
			N/A	
		10,000 Lts.	10,000 Lts.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby 			
			N/A	

