

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001
Fax: 011-23412593, Email :- cfohq.dfire@nic.in, Ph:- 011-23414333

NO. F6/DFS/MS/School/2013/ *N02/907*

DATED: *12/09/13*

FIRE SAFETY CERTIFICATE

Certified that the Nehru Adarsh Sr. Sec. School, East Old Seelampur, Delhi-31, comprised of ground plus one upper floor was granted NOC by this department vide Letter No-F6/MS/DFS/2007/2292 dated 20.8.2007. School building was re-inspected by the officer concerned of this department on 24.08.13 in the presence of Mrs. Pratibha Nagar, Principal of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular No. 262-362 dated 17.01.2005 issued by the Director of Education and that the building is fit for occupancy Group B "Educational Building" with effect from *12/09/13* renewed for a period of three years, subject to conditions printed overleaf.

Issued on *12/09/13* at New Delhi by

(Signature)
179
(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

ok
(Signature)
12.9.13

To,

The Principal

Nehru Adarsh Sr. Sec. School, East Old Seelampur, Delhi-31.

Copy to:-

The Joint Director of Education

(Land & Estate)

Directorate of Education,

Lucknow Road, Delhi -54.

CONDITIONS:

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Nehru Adarsh Sr. Sec. School, East Old Seelampur, Delhi-31.
 2. Building is comprised of : G+1
 3. Type of Occupancy : Educational
 4. Type of Case : Renewal
 5. Details of Previous NOC : Letter No- F6/MS/DFS/2007/2292 Dated 20.8.2007
 6. Fire Safety direction letter No : Old requirements (Circular No. 262-362 dated 17.01.2005)
 7. Date of Inspection : 24.8.13
 8. Name of the Inspecting Officers: : Suresh singh (ADO)
 9. Name of the designation of Officer
 from the building side : Mrs. Pratibha Nagar, Principal
 10. Year of Construction : 1980
 11. Applicant's letter No : PMPS/2013/07/005 dated 25.7.13

S.No	Minimum Standards on fire prevention and fire safety U/R33	Old Requirement	Provided at Site	Remarks MR/NMR
1	Access to building	Required	Provided	MR
	Road width	6 m	3 m	MR/Old Accepted
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits	Required	Provided	MR
	a. Number of Staircases	1 no.	2 no.	MR/Old Accepted
	Upper Floor	1 no.	2 no.	MR/Old Accepted
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases	1.5 m	1.5 m, 1 m	MR/Old Accepted
	Upper Floor	1.5 m	1.5 m, 1 m	MR/Old Accepted
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits	N.A.	N.A.	N.A.
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
	g. Width of Corridor	1.5 m	1.5 m	MR/Old Accepted
h. Door Size	1 m	1 m	MR/Old Accepted	
3	Compartmentation.	Required	Provided	MR
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.	Ventilated		
	Basement	30a/c per hour	N.A.	N.A.
	Upper floor	12 a/c per hour	N.A.	N.A.

5.	Fire Extinguisher	Required	Provided	MR
	Total numbers	04 no.	07 no.	MR/Old Accepted
	types	ABC	ABC	MR/Old Accepted
	IS marking	ISI marked	ISI marked	MR/Old Accepted
6	First-aid-Hose Reels.	Required	Provided	MR
	Total numbers of each floor	01 no.	01 no.	MR/Old Accepted
	Length of hose reel hose	30 m	30 m	MR/Old Accepted
	Nozzle diameter	5 mm	5 mm	MR/Old Accepted
7	Automatic fire detection and alarming system.	N.A.	N.A.	N.A.
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	Yes	MR/Old Accepted
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	N.A.	Yes	MR/Old Accepted
10	Automatic Sprinkler System.	N.A.	N.A.	N.A.
	basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants	N.A.	N.A.	N.A.
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.	N.A.	N.A.	N.A.
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.	Required	Provided	
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level			
	➤ Discharge of pump	220 LPM	220 LPM	MR/Old Accepted
	➤ Head of the Pump	40 m	40 m	MR/Old Accepted
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.

IRN/9

Nehru Adarsh Sr. Sec. School, East Old Seelampur, Delhi-31..

14	Captive Water Storage for Fire Fighting.	Required	Provided	MR
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	2500 Liters	2500 Liters	MR/Old Accepted
15	Exit Signage.	N.A.	N.A.	N.A.
16	Provision of Lifts.	N.A.	N.A.	N.A.
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.	N.A.	N.A.	N.A.
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room	N.A.	N.A.	N.A.
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the Rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Singh
5.9.13

Signature of the Inspecting Officer

Name Suresh Singh

Designation ADO (Shah)



DO/EAST)

Submitted for appraisal please.

Handwritten signature