

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/School/2013/w2/911

Dated: 13 / 08 / 2013


FIRE SAFETY CERTIFICATE

Certified that the **Maharaja Aggarsain Adarsh Public School, DU- Block, Pitampura, Delhi** comprised of **Ground + three upper floors** occupied by **Maharaja Aggarsain Adarsh Public School, DU- Block, Pitampura,** was issued NOC vide this office letter no. F.6/DFS/MS/09/340 dated 05/02/2009. The premises was re-inspected by the officer concerned of this department on 12/08/2013 in the presence of **Smt. Harsh Arya (Principal)**. The premises have therefore, deemed complied with the Director of Education circular Dated 01/03/2011 and the building/ premises is fit for occupancy Class **Educational** with effect from 13 / 08 / 2013 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupied shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 13/08/13 at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph:011-23414250
Cfowz.dfire@nic.in

Copy to:

1. The Principal, Maharaja Aggarsain Adarsh Public School, DU- Block, Pitampura, Delhi.
2. The Director of Education, Govt. of NCT of Delhi.

- N/2 -

Ground + upper three floors

INSPECTION REPORT

1. Name & address of the building : Maharaja Aggasain Adarsh Public School,
2. Type of Occupancy : Educational DU-Block, Pitampura
3. Type of Case : New Case/ Renewal ✓
4. Details of previous NOC : Letter No. F.6/DFs/MS/09/340 Dated: 05/02/2009
5. Fire Safety directives letter No : —
6. Date of inspection : 12/08/2013
7. Name of the Inspecting Officers : D.O S.K. Dua
8. Name and designation of officers from the building side : Smt. Harsh Asya (Principal)
9. Year of Construction : 1999
10. Applicant's letter No. : MAAPS/2013/65 dt. 24/07/13

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE NBC Requirement <i>Circular No 17-1-05</i>	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mtr.	Provided	MR
	• Gate width	Accessible	6mtr. Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Three + Ramp	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	old case 1.35m	2) 1.35m	old case
	• Basements	—	Ramp = 1.72 mtr.	—
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	Two	Provided	MR
	g. Width of Corridor	1.5 mtr.	1.8 mtr.	MR
	h. Door Size	1.0 mtr.	1.0 mtr. with door frame	MR

- 2/3 -

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	NA Open to sky	NA NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	31 ISI marked	Provided Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	Two 30 m 5 mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
8	MOEFA	NA	NA	NA
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 		N/A	
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	R. NA	P NA (Provided)	NA (MR)

- M/4 -

cost required at that time.

	<ul style="list-style-type: none"> Number of hydrants per floor Hose Box 	NR	Provided (Two)	MR
		NR	Provided (Two)	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 		N/A	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
			N/A	
		1) 450 LPM	Provided	MR
		2) 220 LPM 40 mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NR	50,000 lts.	MR
		NR	Provided	MR
		NR	Provided	MR
		NR	Required	MR
		20,000 lts.	20,000 lts.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby 		N/A	

1 - 1/5 -

	<ul style="list-style-type: none"> • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply	Repaired	Di. set - 70/10A & 15 KVA	M/R
18	Refuge Area.			
	➤ Total Area		N/A	
	➤ Location			
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:	No		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer
 Name S. K. Dua
 Designation Div. officer

Signature of the Inspecting Officer
 Name
 Designation

