


NO. F6/DFS/MS/School/2013/ SZ/ 905

DATED: 12/09/13

**FIRE SAFETY CERTIFICATE**

Certified that the New Evergreen Public School, C-138, Vikas Vihar (Bhart Vihar), Kakrola, New Delhi-110078 comprised of ground plus one upper floor was granted NOC by this department vide letter no. F6/MS/DFS/2006/3326 dated 13.11.2006. The premises was re-inspected by the officers concerned of this department on 07.09.2013 in the presence of Sh. Tarun Kumar and observed that fire safety measures are in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi have deemed complied and that the building / premises is fit for occupancy class B "Educational building" with effect from...12/09/13... for a period of **three years**, subject to condition as mentioned below.

Issued on ...12/09/13... at New Delhi by

  
(Dr. G.C. Misra)  
Chief Fire Officer  
Delhi Fire Service

Copy to,

1. The Director (Edu.), SDMC, 23<sup>rd</sup> floor, Civic Centre, Minto Road, New Delhi
2. Mr. Tarun Kumar (Manager), New Evergreen Public School, C-138, Vikas Vihar (Bhart Vihar), Kakrola, New Delhi-110078.

**Conditions for the validity of fire safety certificate**

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1	Name & address of the building	New Evergreen Public School, C-138, Vikas Vihar (Bhart Vihar), Kakrola, New Delhi-110078.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal		
4	Details of previous NOC	F6/DFS/2006/3326 Dated 13.11.2006		
5	Fire safety directives letter No	Edu. Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	07.09.2013		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Tarun Kumar ( Manager )		
9	Year of construction			
10	Applicant's letter No.	Nil Dated 30.08.2013	(Ground plus one upper floor)	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
--------	---	-----------------	------------------	------------------

<b>1</b>	<b>Access to building</b>			
	1) Road width	Required	6 Mtr Provided	MR
	2) Gate width	Old Case	5 Mtr Provided	MR
	3) Width of internal road	N/A	N/A	N/A

<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	Old Case	2 Nos. Provided	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	Old Case	1.00 & 0.97 Mtr Provided	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Required	One Provided	MR
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	Old Case	1 Mtr Provided	MR

<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

<b>4</b>	<b>Smoke Management system.</b>			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Natural Vent.	MR

<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers		5 Nos	MR
	Types		ABC	MR
	ISI marking	ISI	Provided	MR

6	<b>First-Aid Hose Reels.</b>				
	total numbers on each floor	N/A	One Provided		MR
	Length of Hose reel hose	N/A	30 Mtr Provided		MR
	Nozzle Diameter	N/A	5mm provided		MR
7	<b>Automatic fire detection and alarming system</b>				
	Type of detectors	N/A	N/A		N/A
	location of Main Panel	N/A	N/A		N/A
	location of Repeater panel	N/A	N/A		N/A
	Alternate source of power	N/A	N/A		N/A
	hooter's location	N/A	N/A		N/A
8	<b>MOEFA</b>	N/A	N/A		N/A
9	<b>Public Address System.</b>	Required	Provided		MR
10	<b>Automatic Sprinkler System.</b>				
	basement	N/A	N/A		N/A
	upper floors	N/A	N/A		N/A
	sprinkler above false ceiling	N/A	N/A		N/A
11	<b>Internal Hydrants</b>				
	Size of riser/down-corner	N/A	N/A		N/A
	Number of Hydrants per floor	N/A	N/A		N/A
	hose Box	N/A	N/A		N/A
12	<b>Yard Hydrants.</b>				
	total number of hydrants	N/A	N/A		N/A
	hose box	N/A	N/A		N/A
13	<b>Pumping arrangements</b>				
	<b>1. Ground level</b>				
	a. Discharge of main Pump	N/A	N/A		N/A
	b. Head of main pump	N/A	N/A		N/A
	c. Number of main pumps	N/A	N/A		N/A
	d. jockey pump out put	N/A	N/A		N/A
	e. jockey pump head	N/A	N/A		N/A
	f. Standby Pump output	N/A	N/A		N/A
	g. Stanby Pump head	N/A	N/A		N/A
	h. Auto Starting/Manual stopping	N/A	N/A		N/A
	pump house access	N/A	N/A		N/A
	<b>2. Terrace level</b>				
	a. Discharge of pump	N/A	280 LPM Provided		MR
	b. head of the pump	N/A	30 Mtr Provided		MR
	c. Power supply	N/A	Provided		MR
	d. Auto starting of pump	N/A	Provided		MR
14	<b>Captive water storage for fire fighting</b>				
	1. Underground tank capacity	N/A	N/A		N/A
	a. Draw-off connection	N/A	N/A		N/A
	b. fire service inlet	N/A	N/A		N/A
	c. Access to tank	N/A	N/A		N/A
	Over head tank Capacity	N/A	2500 Ltr Provided		MR
15	<b>Exit Signage.</b>	N/A	N/A		N/A
16	<b>Provision of lifts.</b>				
	a. Pressurization of lift shaft	N/A	N/A		N/A
	b. pressurization of lift lobby	N/A	N/A		N/A
	c. communication in lift car	N/A	N/A		N/A
	d. Fireman's grounding switch	N/A	N/A		N/A
	e. Lift signage	N/A	N/A		N/A

*Ray*

N/S

	<b>Standby power supply</b>	N/A	N/A	N/A
	<b>Refuge Area.</b>	Not Required		
	total area			
	location			
<b>19</b>	<b>Fire control room</b>			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
<b>20</b>	<b>Special Fire Protection systems for protection of special risks, if any:</b>	<b>N/A</b>		

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/ Accordingly DFA is put up for your approval and signature please.



*S.P. Bhardwaj*  
 Signature of the Inspecting Officer  
 Name S.P. Bhardwaj  
 Designation ADO (Dwarka)