

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/SCHOOL/2013/w2/918

Dated: 16/09/2013

**FIRE SAFETY CERTIFICATE**

Certified that the **Vishal Bharti Public School** at **A-1 Block, Paschim Vihar, New Delhi -110063**, comprised of **Ground + Two upper floors** only owned / occupied by **Modern Delhi Citizen Educational Society (Regd.)**, has already been issued Fire Safety Certificate **vide letter No.F6/DFS/MS/2010/2014 dated 08.07.2010** have deemed complied with the fire prevention and fire safety requirements in accordance with circular issued by Directorate of Education, Govt. of NCT of Delhi vide letter No. 262-362 dated 17.01.2005 and verified by the officer concerned of Fire Service on **13.08.2013** in the presence of **Smt. Anita Saxena (Vice-Principal)** and that the building / premises is fit for occupancy class **Educational** with effect from **16 / 09 / 2013** for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules,2010.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

**Issued on** 16/09/13 **at New Delhi by.**

  
(SANTOSH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
[cfowz.dlfire@nic.in](mailto:cfowz.dlfire@nic.in)

Copy to :-

1. Smt. Anita Saxena (Vice-Principal), Vishal Bharti Public School, A-1 Block, Paschim Vihar, New Delhi -110063.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.



**INSPECTION REPORT**

1. Name & address of the building: Vishal Bharti Public School  
A-1, Block, Darchem Vihar, ND-63
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : Letter No F.6 / DFS / MS / 2010 / 2014 dt 8<sup>7</sup>/<sub>10</sub>
5. Fire Safety directives Letter No. : D.O.E circular 17.01.05
6. Date of inspection : 13/08/2013
7. Name of the Inspecting Officer : A.K. JAISWAL
8. Name and designation of Officer  
from the building side : Smt. Anita Saxena  
(Vice Principal)
9. Year of Construction : -----
10. Applicant's letter No. : N B P S / A O / 2013 / 677 dt 29<sup>7</sup>/<sub>13</sub>

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL / D.O.E 17.05 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	---	---	---
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	NA	NA	NA
	b. Width of staircases	old case		
	• Upper floors	old case	old case	old case
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door			
	• Pressurization		NR	
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	1.50 Mtr	Provided	MR
	f. Door Size	1.00 Mtr	Provided	MR

N12

3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>		NR	
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour		NR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	12 ABC/CO2 ISI marked	21 Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	(2) 30 Mtr. 6.5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detector</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>			NR
8.	MOEFA			NR
9.	Public Address System	NR	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>			NR

Internal Hydrants			
• Size of riser/down- comer	100 mm	Provided	MR
• Number of hydrants per floor	1	Provided	MR
• Hose Box	1	Provided	MR
12. Yard Hydrants			
• Total number of hydrants		NR	
• Hose Box			
13. Pumping Arrangements			
• Ground Level			
• Discharge of main pump			
➤ Head of main pump			
➤ Number of main pumps			NR
➤ Jockey pump out put			
➤ Jockey pump head			
➤ Standby Pump out put			
➤ Standby Pump Head			
➤ Auto Staring/Manual stopping			
➤ Pump House Access			
• Terrace level			
➤ Discharge of pump	220 lpm	450 lpm 180 lpm	MR
➤ Head of the pump	40 MPH	Provided	MR
➤ Power supply	Required	Provided	MR
➤ Auto starting of pump	Required	Provided	MR
14. Captive water Storage for fire fighting			
• Under ground tank capacity	NR	25,000 lbs	NR
➤ Draw of connection	NR	Provided	NR
➤ Fire service inlet	NR	Provided	NR
➤ Access to tank	Required	Provided	NR
• Overhead Tank capacity	✓ 2500 lbs	5,000 lbs	MR

		Required	Provided	
15	Exit Signage			NR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft			
	➤ Pressurization of lift lobby			
	➤ Communication in lift Car			NR
	➤ Fireman's Grounding Switch			
	➤ Lift Signage			
17.	Standby power supply		NR	
18.	Refuge Area		NR	
	➤ Total area			
	➤ Location			NR
19.	Fire control room			
	➤ Detector system panel			
	➤ Flow Switch Panel			
	➤ PA System Panel			NR
	➤ Batter backup			
	➤ Building Floor Plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

.....

N15

~~A.K. Jaiswal~~  
5/9/13

Signature of the Inspecting Officer

Name

(A.K. JAISWAL)

Designation

ADP (JWP)

Signature of the Inspecting Officer

Name

Designation