

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No. F.6/DFS/MS/School/2013/ 52/940

Dated: 20/09/13

FIRE SAFETY CERTIFICATE

Certified that the **Oxford Sr. Secondary School** located at E-Block, Vikaspuri, New Delhi-110018 comprised of Basement, Ground floor plus three upper floors, having total 113 rooms (Including Class Rooms, Offices, Sci. Lab, Comp. Lab, Library & Sports Room etc.) was issued NOC by this department vide letter No.F.6/DFS/MS/2010/2512 dated 30.08.2010. The School building was re- inspected by the officer concerned of this department on 09.09.2013 in the presence of Capt. Shrikant Sharma (Manager) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....20/09/13.....at New Delhi.


(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Manager,
Oxford Sr. Secondary School,
E- Block, Vikaspuri, New Delhi-18.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi – 110 054



Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provisions of the Building Bye Laws, 1983.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Oxford Sr. Secondary School, E-Block, Vikaspuri, ND-18
2. Type of Occupancy : Educational
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F6/DFS/MS/2010/2512 Date 30/8/10
5. Fire Safety Directives letter No : _____
6. Date of inspection : 09-09-2013
7. Name of Inspecting Officer : ADO Sandeep Duggal
8. Name and designation of officers
From the building side : capt. Shrikant Sharma (Manager)
9. Year of Construction : 1994-1995
10. Applicant's letter No. : OSSS/VP/204/2013 dated 17/08/2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible —	12 mtrs 4m (2 NO'S)	Provided (MR) MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases <ul style="list-style-type: none"> • Upper Floors • Basements 	04 NO'S 04 NO'S	04 NO'S 04 NO'S	MR MR
	b. Width of staircases <ul style="list-style-type: none"> • Upper Floor • Basements 	150 cms 150cms	3 NO'S of 180cms, 1 no 133cms 160, 157, 190 & 75cms	MR (old case) MR (old case)
	c. Protection of exits <ul style="list-style-type: none"> • Fire check door • pressurization 	— —	— —	— —
	d. No. of continuous staircases to terrace	—	03 NO'S	—
	e. Width of Corridor	—	240 & 250 cms	—
	f. Door Size	1mtrs	112 cms x 208 cms	MR
3.	Compartmentation <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	— — — — —	— Sealed — — —	— — — — —
4.	Smoke Management System <ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	Exhaust fans Natural Ventilation	MR MR

N/4

		12 a/c per hour	—	←
5.	Fire Extinguishers			
	• Total numbers	25 No's	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	03 No's	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	—	—	—
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hooters' Location	—	—	—
8.	MOEFA			
9.	Public Address System			
		—	Provided	—
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	—	03 No's	MR
	• Hose Box	—	03 No's	MR
12.	Yard Hydrants			
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	—	—	—
	➤ Head of Main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey Pump out put	—	—	—
	➤ Jockey pump head	—	—	—
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—
	➤ Auto Starting/Manual stopping	—	—	—

N/S

Oxford Sr. Secondary School, E-Block, Vikaspuri, MD-18

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
		450 lpm	2100 ¹⁵ 450+180 lpm	MR (old case)
		40m	40m each	—
		—	—	—
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	50,000 lpm Required	50,000 lpm Provided	MR MR
		Required	Provided (2-way)	MR
		—	Provided	MR
		5000 lpm	5000 lpm	MR (old case)
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	No lift do do do do
17.	Standby power supply	—	140 kVA	—
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
		—	—	—
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
20.	Special Fire Protection System for Protection of special Risks, if any:	—	—	—

SAN

N/6

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to ~~grant~~ ^{renewal} Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Note :- ① School Building premises has main block comprised of two separate basements, Ground floor plus three upper floors served by 04 Nos of staircases 160, 157, 190 & 75 cms. for basements and 04 Nos of staircases 180, 180, 180 & 133 cms for upper floors.
② There are less than 45 students in each class as per formk-declaration given by the Manager of School. FSC is recommended please.

Sandeep
13/9/13

Signature of Inspecting Officer

Name

Sandeep Duggal

Designation

Asstt. Divisional Officer

Signature of Inspecting Officer

Name

Designation

