

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No. F.6/DFS/MS/School/2013/82/939

Dated: 20/09/13

FIRE SAFETY CERTIFICATE

Certified that the **Rich Harvest Public School** located at A-1 Block, Janak Puri, New Delhi-110058 comprised of Basement, Ground floor plus two upper floors, having total 40 rooms (Including Class Rooms, Offices, Sci. Lab, Comp. Lab, Library & Sports Room etc.) was issued NOC by this department vide letter No.F.6/MS/DFS/2006/859 dated 07.04.2006. The School building was re- inspected by the officer concerned of this department on 09.09.2013 in the presence of Sh. Rajesh Vij (Chairman) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....20/09/13.....at New Delhi.


(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Chairman,
Rich Harvest Public School,
A-1 Block, Janak Puri, New Delhi-58.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110 054



Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provisions of the Building Bye Laws, 1983.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

N/4

Basement, Ground plus two upper floors

INSPECTION REPORT

1. Name & address of the building : Rich Harvest Public School, A-1 Block, Janakpuri, ND-58
2. Type of Occupancy : Educational
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F6/MS/DFS/2006/859 Date 07/04/2006
5. Fire Safety directives letter No : F6/DFS/MS/DF/2001/461 dated 16/07/2001
6. Date of inspection : 09-09-2013
7. Name of Inspecting Officer : ADO Sandeep Duggal
8. Name and designation of officers
From the building side : Mr Rajesh Vij (Chairman)
9. Year of Construction : 2001
10. Applicant's letter No. : Nil dated 03/06/2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks
1.	Access to building			MR/NMR
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>Accessible</p> <p>05 MTR</p>	<p>8mtr</p> <p>4Nos 555, 485, 485, & 485 cms</p>	<p>MR</p> <p>MR</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<p>02 Nos</p> <p>02 Nos</p>	<p>02 Nos</p> <p>02 Nos</p>	<p>MR</p> <p>MR</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	<p>—</p> <p>—</p>	<p>155cms & 155cms</p> <p>135cms & 135cms</p>	<p>MR</p> <p>MR (Being old case)</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • pressurization 	<p>Required</p> <p>—</p>	<p>Provided</p> <p>—</p>	<p>MR</p> <p>—</p>
	d. No. of continuous staircases to terrace			
		—	02	—
	e. Width of Corridor			
		—	270 cms	—
	f. Door Size			
		—	90 cms	MR (Being old case)
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<p>Required</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>	<p>Provided</p> <p>Sealed</p> <p>—</p> <p>—</p> <p>—</p>	<p>MR</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<p>30 a/c per hour</p> <p>—</p>	<p>Exhaust Fans</p> <p>Natural Ventilation</p>	<p>MR</p> <p>MR</p>

San

		12 a/c per hour		
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	20 Nos ABC/CO ₂ ISI marked	Provided - do - ISI marked	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 30 m 5 mm	Provided - do - - do -	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	— — — — —	— — — — —	— — — — —
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	Required — —	Provided — —	MR — —
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	— — —	100mm Provided 02 Nos 02 Nos	— — —
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	— —	— —	— —
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping 	— — — — — — — —	— — — — — — — —	— — — — — — — —

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
		—	three no's (600 LPM) one no (360 LPM)	MR (Being old car)
		—	40 m/hp	MR
		—	—	—
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	50000 ltr	50000 ltr	MR
		—	provided	—
		—	provided	—
		—	provided	—
		15000 ltr	provided	MR
15.	Exit Signage.			
16.	Provision of Lifts:			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	—
		—	—	—
		—	provided	—
		Required	-do-	MR
		—	-do-	—
17.	Standby power supply	—	64 KVA	—
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
		—	—	—
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
20.	Special Fire Protection System for Protection of special Risks, if any:	—	—	—

SRB

N/7

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to ^{renewal of} ~~grant~~ Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....



~~Sandeep~~
13/9/13
Signature of Inspecting Officer

Name Sandeep Duggal

Designation Asst. Divisional officer

Signature of Inspecting Officer

Name

Designation