

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/ 2013/22/ 944

Dated: 20 / 08 / 2013

FIRE SAFETY CERTIFICATE

Certified that the Citymen Children Public School at A-53, Raj Park, S.P. Road, Nangloi, New Delhi-110086, comprised of Ground + Three upper floors only owned / occupied by Citymen Children Public School has already been issued Fire Safety Certificate vide letter No. F6/DFS/MS/2010/2544 dated 01.09.2010. The premises was re-inspected by the officer concerned of Fire Service on 09.09.2013 in presence of Miss Micky Kaushik (Teacher) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of circular issued by Director of Education, Govt. of NCT of Delhi vide letter No. 262-362 dated 17.01.2005 and that the building / premise is fit for occupancy class Educational (Group-B) with effect from 20 / 08 / 2013 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.Delhigovt.nic.in

Issued on 20 / 08 / 13 at New Delhi by.


(SANTOKH SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Phone:-23414250
E-mail: cfowz.dlfire@nic.in

Copy to :-

1. The Principal, Citymen Children Public School, A-53, Raj Park, S.P. Road, Nangloi, New Delhi-110086.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.

de
any

Plot Area = 200 yard² [G+3] N6
 total covered Area = 800 yard²

INSPECTION REPORT

1. Name & address of the building: Citymen children Public School
A-53, Raj Park, Sultanpuri Rd.
Educational (G+3) Nangal, Delhi-86
2. Type of Occupancy : Renewal
3. Type of Case : -----
4. Details of previous NOC : Letter No F-6/DFS/MS/2010/2544/1.9.10
5. Fire Safety directives Letter No. : DOE circular No 17/01/2005
6. Date of inspection : 9/9/13
7. Name of the Inspecting Officer : A.K. Jaiswal ADO (JWA)
8. Name and designation of Officer
 from the building side : Miss Micky Kausik (Teacher)
9. Year of Construction : 1993
Nal dt 19/8/13
10. Applicant's letter No. : -----

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL / DOE given Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	old case	old case	old case
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door			
	• Pressurization			MR
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	Old case	Old case	Old case
	f. Door Size	old case	old case	old case

N7				
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour		
		12 a/c per hour		
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	08 ABC/CO ₂ ISI marked	08 Provided Provided	MR MR MR
6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	1 30 Mtr. 6.5 mm	1 Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detector • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 			

M

Internal Hydrants			
• Size of riser/down-comer	150 mm	Provided	MR
• Number of hydrants per floor	Required (one)	Provided (one)	NR
• Hose Box	Required (one)	Provided (one)	MR
12. Yard Hydrants			
• Total number of hydrants		NR	
• Hose Box			
13. Pumping Arrangements			
• Ground Level			
• Discharge of main pump			
➤ Head of main pump			
➤ Number of main pumps			
➤ Jockey pump out put			
➤ Jockey pump head			
➤ Standby Pump out put			
➤ Standby Pump Head			
➤ Auto Starting/Manual stopping			
➤ Pump House Access			
• Terrace level			
➤ Discharge of pump	450 lpm 180 lpm	Provided	NR
➤ Head of the pump	40 MTH	Provided	MR
➤ Power supply	Required	Provided	MR
➤ Auto starting of pump	Required	Provided	MR
14. Captive water Storage for fire fighting			
• Under ground tank capacity		NR	
➤ Draw of connection			
➤ Fire service inlet		NR	
➤ Access to tank			
• Overhead Tank capacity	5,000 lts	5,000 lts	MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft			
	➤ Pressurization of lift lobby			
	➤ Communication in lift Car		NR	
	➤ Fireman's Grounding Switch			
	➤ Lift Signage			
17.	Standby power supply		NR	
18.	Refuge Area			
	➤ Total area		NR	
	➤ Location			
19.	Fire control room			
	➤ Detector system panel			
	➤ Flow Switch Panel			
	➤ PA System Panel			
	➤ Batter backup		NR	
	➤ Building Floor Plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any;	No special Risk seen		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/~~issue shortcomings as noted at serial numbers~~

.....

D. Int Area = 200 yard^2 \rightarrow NI

Cityman Children^{N/10} Public School, Nangloi

~~A.K. Jaiswal~~
9/9/13

Signature of the Inspecting Officer

Name

(A.K. JAISWAL)

Designation

ADO/(JWP)

Signature of the Inspecting Officer

Name

Designation