

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/2013/W2/954

Dated: 24/09/2013

FIRE SAFETY CERTIFICATE

Certified that the Leo Filling Station located at Pocket-E, Sector-18, Rohini Delhi-110085 owned / occupied by Leo Filling Station was issued NOC by this department for storage of petroleum Class 'A' & 'B' vide this office letter No F-5/(3A)/DFS/99/376 dated 24/08/1999. The retail outlet (petrol Pump) was re-inspected by the officer concerned of this department on 14/05/2013 in the presence of Sh. Ajay Kumar manager and found that the Filling Station have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and **that the premise is fit for storage of Petroleum Class A & B** **W.e.f.** the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

1. "No Smoking" and "Not to use mobile Phone" sign board should be displayed in such a manner as to be easily readable by all persons.
2. No Trade Susceptible to Cause Ignition Petroleum vapors by generating heat, mechanical / electric spark should be allowed with in the premises and its vicinity.
3. 04 nos of Co2 gas type ISI capacity of 4.5 kg, 02 nos of ABC stored pressure power type ISI capacity 05 kg and 01 numbers of AFFF type ISI capacity 50 ltrs should be provided and maintained in proper working order.
4. The workers employed at the petrol pump must be taught the correct method of operation and maintenance of record of the extinguishers be ensured.
5. Overhead electric cable should not be allowed across the licensed premises.
6. Boundary wall of 6 feet high with fencing over the wall should be provided.

Issued on 24/09 / 2013 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. Sh Shailender Kumar Gupta (Partner), Leo Filling Station, Pkt-E, Sec-18, Rohini, Delhi-110085

