

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/2013/953

Dated: 24 / 08 / 2013

FIRE SAFETY CERTIFICATE

Certified that the Munni Garg, Plot No J-116, Sector -4, Bawana Industrial Area, Delhi-110039. comprised of Basement + Ground and First floor owned / occupied by M/s Munni Garg have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concern of Fire Service on 03 / 09 / 2013 in presence of Munni Garg of the factory and that the premise is fit for **Class G-2 (ii) industrial occupancy** with effect from 24 / 08 / 2013 for a period of **three years**, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 24/08/13 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in



Copy to:

1. The Munni Garg, Plot No J-116, Sector -4, Bawana Industrial Area, Delhi-110039.
2. Executive Engineer (Building), North Delhi Municipal Corporation, Zonal building, Narela Zone, Delhi 110040

INSPECTION REPORT

1. Name & address of the building: Muni Garg, J-116, Sec-4, Bawana Indl. Area Delhi.
2. Type of Occupancy : Industrial
3. Type of Case : New Case
4. Details of previous NOC : Letter No - Nil Dated - Nil
5. Fire Safety directives letter No : Moderate Hazard G-2(ii)
6. Date of inspection : 03/09/2013
7. Name of the Inspecting Officers : Do (NW) S.S. Tuli
8. Name and designation of officers
from the building side : Sh. Sunil Garg
9. Year of Construction : 2010
10. Applicant's letter No. : Nil old Nil, ODD 5318 Dated 20/05/2013

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	12 M	P	M/R
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	---	---	---
	• Upper Floors	2	2	M/R
	• Basements	2	2	M/R
	b. Width of staircases			
	• Upper Floors	150 cms	2 staircases of 150 cms one pucca and one iron staircase provided	M/R
	• Basements			
	c. Protection of exits	150 cms	-DO-	M/R
	• Fire check door			
	• Pressurization	R	P	M/R
	e. No. of continuous staircases to terrace	---	---	---
	g. Width of Corridor	ONE	ONE	M/R
	h. Door Size	---	---	---
3	Compartmentation.			
	• Fire check door	R	P	M/R
	• Sealing of electrical shafts	---	---	---
	• Fire Rating of shaft door	---	---	---
	• Water Curtain	---	---	---
	• Fire Dampers	---	---	---
4	Smoke Management System.			
	• Basements	30 a/c per hour	Exhaust fans provided	M/R
	• Upper floors			

	<ul style="list-style-type: none"> Types IS marking 	ISI marked	ABC	M/R
			P	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One at each floor 30 m 5 mm	P	M/R
			P	M/R
			P	M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/R	NP	N/A
		—	—	—
		—	—	—
		—	—	—
		R	P	M/R
8	MOEFA	R	P	M/R
9	Public Address System.	N/A	N/A	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	R	P	M/R
		R	P	M/R
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	4"	P	M/R
		NR	One at each floor	—
		NR	P	—
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NR	NP	N/A
		NR	NP	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
		N/A	NP	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		900 LPM	P	M/R
		40 M	P	M/R
		R	15 K P	M/R
		R	P	M/R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	—	—	—
		—	—	—

