

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DFS/MS/EH/2013/W2/955

Dated: 24/08/2013

FIRE SAFETY CERTIFICATE

Certified that the M/s PYRAMIDS Restaurant located at 12, Roshanara Road, Delhi-110007 was granted Fire Safety Certificate by this department vide letter no F-6/ DFS MS/EH/2010/1566 Dated 28/05/2010. The premises was re-inspected by the officers concerned of this department on 30 / 08 / 2013 in the presence of Sh. Amar Sajwan, Manager and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit for Assembly occupancy with effect from 24 / 08 / 2013 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of Delhi Fire Service Rules, 2010.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the restaurant are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 24/08/13 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Distt. Excise Officer (Restt) Deptt, of Excise Entertainment and Luxury tax Govt. of NCT of Delhi, L& N Block, Vikas Bhawan, IS State, New Delhi.
2. Sh. Amar Sajwan, Manager, PYRAMIDS Restaurant, 12, Roshanara Road, Delhi-110007

G.F only

INSPECTION REPORT

1. Name & address of the building : M/S Pyramid Restaurant (with 72 seats) in two halls
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DFS/MS/EH/2010/1566 Dated 28/05/2010.
5. Fire Safety directives letter No : F-6/6/TSM/Inspection/2004/95 dated 04/04/2005
6. Date of inspection : 30 / 08 / 2013
7. Name of the Inspecting Officers : DO (NW)
8. Name and designation of officers
from the building side : Amar Sajwan, Manager
9. Year of Construction : 2005
10. Applicant's letter No. : Nil Dated 19/08/2013.

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	P	M/R
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	N/A	N/A	N/A
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases	N/A	N/A	N/A
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A

	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	Old case	Three doors provided	M/R
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Exhaust fan provided	M/R
5.	Fire Extinguishers			
	• Total numbers	12 ABC Type	12	M/R
	• Types		ABC	M/R
	• IS marking	ISI marked	Yes	M/R
6	First-Aid Hose Reels.			
	• Total numbers on each floor	one	Provided	M/R
	• Length of hose reel hose	30 m	P	M/R
	• Nozzle diameter	5 mm	P	M/R
7	Automatic fire detection and alarming system.			
	• Type of detectors	N.R	N.R	N.R
	• Location of Main Panel	N.R	N.R	N.R
	• Location of Repeater Panel	N.R	N.R	N.R
	• Alternate source of power	N.R	N.R	N.R
	• Hooters' Location	N.R	N.R	N.R
8	MOEFA	R	P	M/R

9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• Upper Floor	R	P in Restaurant	M/R
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	P	N/A
	• Hose Box	N/A	P	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	225LPM	P	M/R

	➤ Discharge of pump	35m	P	M/R
	➤ Head of the pump	R	P	M/R
	➤ Power Supply	R	P	M/R
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	R	Provided	M/R
	➤ Fire service inlet	R	Provided	M/R
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	2500 ltr	Provided	M/R
15	Exit Signage.	R	P	M/R
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	R	P	M/R
17	Standby power supply	R	Provided	M/R
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A

	<ul style="list-style-type: none"> Batter backup Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	--	--	--

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

[Handwritten Signature]
9/9/13
DO(NW)

leave.