

NO. F6/DFS/MS/School/2013/SZ/ 968

DATED: 24/09/13

**FIRE SAFETY CERTIFICATE**

Certified that the Vandana Kindergarten at Sector 10, Phase-1, Dwarka, New Delhi-110075 comprised of ground plus two upper floors was granted NOC by this department vide letter no. F6/MS/DFS/2011/183 dated 31.01.2011. The premises was re-inspected by the officers concerned of this department on 21.09.2013 in the presence of Sh. V.K, Tiwari and observed that fire safety norms as required under Rule 33 of Delhi Fire Service Rules, 2010 are deemed complied and that the building / premises is fit for occupancy class B "Educational building" with effect from 24/09/13 for a period of **three years**, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on 24/09/13 at New Delhi by



(Dr. G.C. Misra)  
Chief Fire Officer  
Delhi Fire Service

Copy to,

1. The Dy. Director, (Education), G.N.C.T..of Delhi, Old Secretariat, New Delhi-110054.
2. The Principal, Vandana Kindergarten at Sector 10, Phase-1, Dwarka, New Delhi-110075.

**Conditions for the validity of fire safety certificate**

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1	Name & address of the building	Vandana Kindergarten at Sector 10, Phase-1 Dwarka, New Delhi-110075.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal		
4	Details of previous NOC	F6/MS/DFS/2011/183 dated 31.01.2011		
5	Fire safety directives letter No	No		
6	Date of inspection	21.09.2013		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. V.K. Tiwari		
9	Year of construction	2007		
10	Applicant's letter No.	Nil dated 10.09.2013	(Ground plus two upper floors)	
Old Case				

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	<b>Access to building</b>			
	1) Road width	Required	10 Mtr Provided	MR
	2) Gate width	Old Case	5 Mtr Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	Old Case	2 Nos. Provided	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	Old Case	1.5 Mtr Provided each.	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Required	One Provided	MR
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	Old Case	1 Mtr Provided	MR
3	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Natural Vent.	MR
5	<b>Fire Extinguishers</b>			
	total numbers		8 Nos	MR
	Types		Co2 & ABC	MR
	ISI marking	ISI	Provided	MR

<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	Required	One Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
<b>7</b>	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
<b>8</b>	<b>MOEFA</b>	N/A	N/A	N/A
<b>9</b>	<b>Public Address System.</b>	Required	Provided	MR
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	100 MM Provided	MR
	Number of Hydrants per floor	N/A	One Provided	MR
	hose Box	N/A	One Provided	MR
<b>12</b>	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
<b>13</b>	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	Old Case	450 & 180 LPM Provided	MR
	b. head of the pump	Old Case	40 Mtr Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
<b>14</b>	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	MR
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	Old Case	10,000 Ltr Provided	MR
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16</b>	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/G

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	N/A		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/

Accordingly DFA is put up for your approval and signature please.

  
Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)