

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
Fax: 23412593, Email: cfohqdlfire@nic.in, Tel:- 011-23414333

NO.F6/DFS/MS/school/2013/ND21971

Dated: 25/09/13

FIRE SAFETY CERTIFICATE

Certified that **Govt Sarvodaya Vidyalaya, Gokhle Marg, Mori Gate, Delhi-6** comprised of stilt plus three upper floors. The school premises was inspected by the officer concerned of this department on 30.08.2013 in presence of Principal of the school and found that the School management have complied with fire prevention and fire safety requirements in accordance with the Delhi Fire Service Act-2010 and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the following conditions.

Issued on ---25/09/13--- at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-54.
2. The Govt Sarvodaya Vidyalaya, Gokhle Marg, Mori Gate, Delhi-6

Conditions for the validity of fire safety certificate

- a. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- b. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
- c. The trained staff should be available round the clock.
- d. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
- e. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
- f. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: Govt. Sarvodaya Vidyalaya, Gokul Marg
Mori Gate, Delhi-110006
2. Type of Occupancy : Educational
3. Type of Case : Fresh
4. Details of previous NOC : Letter No - NIL
5. Fire Safety directives Letter No. : F.16/Estt/EC/Fire Safety/2011/3398 & to 3398 Dt.1/3/11
6. Date of inspection : 30-08-13
7. Name of the Inspecting Officer : Sanjay Kumar Tomar, ADO
8. Name and designation of Officer from the building side : Sh. Harad Rai (Principal)
9. Year of Construction : 1973
10. Applicant's letter No. : 137/GSV/GM/2013 dated 10/07/2013

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible to fire engine	Provided 8m wide app	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Two	Two Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 mtr	1.50mtr each Provided	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	One	Two	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	N/A	N/A	N/A

N/A

3.	Compartmentation				
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 				
4.	Smoke managements System				
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour			
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour			
5.	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	18 nos. CO ₂ , ABC & DCP ISI marked	18 No. Provided	MR	
			Provided	MR	
			Provided	MR	
6.	First - Aid Hose Reels				
	<ul style="list-style-type: none"> • Total numbers on each floor 	One	Two Provided	MR	
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 mtr	Provided	MR	
	<ul style="list-style-type: none"> • Nozzle diameter 	5mm	Provided	MR	
7.	Automatic fire detection and alarming system				
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 				
8.	MOEFA				
9.	Public Address System				
10.	Automatic Sprinkler System				
	<ul style="list-style-type: none"> • Basements 				
	<ul style="list-style-type: none"> • Upper Floor 				

M


8

	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down- comer • Number of hydrants per floor • Hose Box 		N/A	
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 		N/A	
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 		N/A	
		-	-	-
		450 LPM	Provided	MR
		40 M	Provided	MR
		Required	Provided	MR
		N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 		N/A	
		10,000 ltrs	15,000 ltr Provided	MR
15	Exit Signage	Required	Provided	MR

	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 				
17.	Standby power supply	N/A	N/A	N/A	
18.	Refuge Area				
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 				
19.	Fire control room				
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Batter backup ➤ Building Floor Plans 				
20.	Special Fire Protection Systems for Protection of special Risks, if any;	-	-	-	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue ~~shortcomings as noted at serial numbers~~



Signature of the Inspecting Officer

Name

Designation

DO CEO

submitted please

16-9-13

Signature of the Inspecting Officer

Name

Designation

Asst. Dirnl. Officer

Sanjay Kumar Tomar

[Signature]

Received on 16-9-13