

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
Fax: 23412593, Email: cfohq@dlfire@nic.in, Tel:- 011-23414333

NO.F6/DFS/MS/school/2013/NDZ/972

Dated: 25/09/13

FIRE SAFETY CERTIFICATE

Certified that **Rajkiya Pratibha Vikas Vidyalaya, Raj Niwas Marg, Delhi-54** comprised of ground floor plus two upper floors with one separate auditorium. The school premises was inspected by the officer concerned of this department on 22.08.2013 in presence of Sh. S. D. Sharma , Principal of the school and found that the School management have complied with fire prevention and fire safety requirements in accordance with the Delhi Fire Service Act-2010 and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the following conditions.

Issued on -----25/09/13----- at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-54.
2. The Rajkiya Pratibha Vikas Vidyalaya, Raj Niwas Marg, Delhi-54

Conditions for the validity of fire safety certificate

- a) All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- b) Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
- c) The trained staff should be available round the clock.
- d) Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
- e) The certificate may not be treated in any case for regularization of unauthorized construction, if any.
- f) The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: Rajkiya Pratibha Vikas Vidyalaya
Raj Niwas Marg, Delhi-54
2. Type of Occupancy : Educational
3. Type of Case : New Case/Old School
4. Details of previous NOC : Letter No N12
5. Fire Safety directives Letter No. Director of Education & No. F.16/Estab/CR/Fire Safety/2011/3298-3328
DF-11311
6. Date of inspection : 22-08-2013
7. Name of the Inspecting Officer : S.K. Tomar, ADO (SPM)
8. Name and designation of Officer SR.S.D.Sharma (Principal)
from the building side
9. Year of Construction : 1951
10. Applicant's letter No. : RPVV/RNM/2013/530 Dated - 02-07-2013

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible to fire engine	> 6mtr Provided	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Two	Three	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 mtr Each	1.50mtr each	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	N/A	N/A	N/A

4/11

3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	26 ABC Powder, CO ₂ ISI marked	Provided	MR
	• Types		Provided	MR
	• IS marking		Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	One	03 Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A

16. Provision of Lifts				
➤	Pressurization of Lift Shaft	N/A	N/A	N/A
➤	Pressurization of lift lobby	N/A	N/A	N/A
➤	Communication in lift Car	N/A	N/A	N/A
➤	Fireman's Grounding Switch	N/A	N/A	N/A
➤	Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A



The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue ~~shortcomings as noted at serial numbers~~

Received 17-9-13

Signature of the Inspecting Officer

Name

Designation

DOCCO

submitted Recd.

17-9-13

[Signature]
23/8/13

Signature of the Inspecting Officer

Name

Sanjay Kumar Tomar

Designation

Asstt. Dirn. Officer (SPM)