

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/GH/2013/W2/975

Dated: 26/09/2013

FIRE SAFETY CERTIFICATE

Certified that the **Baba Guest House located at A-17, Kewal Park Extension, Azadpur, New Delhi** Comprised of **Ground + three upper floors** owned and occupied by **Sh Har Prasad** has already been issued fire safety certificate vide **Letter No F-6/DFS/MS/GH/2010/2882 dated 05/10/2010**. The premises was re-inspected by the officer from this department on dated **11/09/2013** in the presence of **Sh Laxman (Manager)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have there fore deemed complied with the fire prevention and fire safety in accordance with rule 33 of the Delhi Fire Service Rule, 2010 for a period of **three years**, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 26/09/13 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:-

1. The Additional Commissioner of Police (Lic), 1st floor, Police Station, Defense Colony, New Delhi.
2. The owner Baba Guest House, A-17, Kewal Park Extension, Azadpur, New Delhi

INSPECTION REPORT

1. Name & address of the building : Baba Guest House, A-17, Kewal Park Extension, Azadpur,
2. Type of Occupancy : Guest House
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DFS/MS/GH/2010/2882 dated 05/10/2010
5. Fire Safety directives letter No : --
6. Date of inspection : 11/09/2013
7. Name of the Inspecting Officers : DO NW (S.S Tuli)
8. Name and designation of officers
from the building side : Laxman (Manager)
9. Year of Construction : 1998 (10/11/2009)
10. Applicant's letter No. : 42169/Addl.CP/Lic(H) Dated 22/08/2013

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Requirement | Provided at site | Remarks MR/NMR |
|--------|---|--------------------------------------|--------------------------------------|--------------------------------------|
| 1 | Access to building | | | |
| | <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road | Accessible | Old case | M/R |
| | | -- | -- | -- |
| | | -- | -- | -- |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floors • Basements | 1 -- | 1 -- | M/R -- |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floors • Basements | Old case -- | Old case -- | M/R -- |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> • Fire check door • Pressurization | -- -- | -- -- | -- -- |
| | d. No. of continuous staircases to terrace | 1 | 1 | M/R |
| | e. Width of Corridor | -- | -- | -- |
| | f. Door Size | Old case | Old case | M/R |
| 3 | Compartmentation. | | | |
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers | N.A. N.A. N.A. N.A. N.A. | N.A. N.A. N.A. N.A. N.A. | N.A. N.A. N.A. N.A. N.A. |
| 4 | Smoke Management System. | | | |
| | <ul style="list-style-type: none"> • Basements • Upper floors | 30 a/c per hour 12 a/c per hour | N.A. N.A. | N.A. N.A. |

| | | | | |
|----|---|---|--|---|
| | <ul style="list-style-type: none"> Total numbers Types IS marking | 08 ISI marked | Provided ABC -- | M/R -- -- |
| 6 | First-Aid Hose Reels. | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | 1 30 m 5 mm | Provided -- -- | M/R -- -- |
| 7 | Automatic fire detection and alarming system. | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | N.A. N.A. N.A. N.A. N.A. | N.A. N.A. N.A. N.A. N.A. | N.A. N.A. N.A. N.A. N.A. |
| 8 | MOEFA | R | P | M/R |
| 9 | Public Address System. | -- | -- | -- |
| 10 | Automatic Sprinkler System. | | | |
| | <ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling | N.A. N.A. N.A. | N.A. N.A. N.A. | N.A. N.A. N.A. |
| 11 | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box | 4" -- -- | Provided -- -- | M/R. -- -- |
| 12 | Yard Hydrants. | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | N.R. -- | N.P. -- | N.A. -- |
| 13 | Pumping Arrangements. | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump | N.A. N.A. N.A. N.A. N.A. N.A. N.A. N.A. N.A. 900 LPM -- -- -- | N.A. N.A. N.A. N.A. N.A. N.A. N.A. N.A. N.A. Provided -- -- | N.A. N.A. N.A. N.A. N.A. N.A. N.A. N.A. N.A. M/R -- -- |
| 14 | Captive Water Storage for fire fighting. | | | |

| | | | | |
|----|---|----------------|-----------------|------------|
| | <ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity | N.A. | N.A. | N.A. |
| | | N.A. | N.A. | N.A. |
| | | 5000Ltr | Provided | M/R |
| 15 | Exit Signage. | R | Provided | M/R |
| 16 | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage | N.A. | N.A. | N.A. |
| | | N.A. | N.A. | N.A. |
| | | N.A. | N.A. | N.A. |
| | | N.A. | N.A. | N.A. |
| | | N.A. | N.A. | N.A. |
| 17 | Standby power supply | R | 15 KVA | M/R |
| 18 | Refuge Area. | | | |
| | <ul style="list-style-type: none"> ➤ Total Area ➤ Location | N.A. | N.A. | N.A. |
| | | N.A. | N.A. | N.A. |
| 19 | Fire Control Room | | | |
| | <ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans | N.A. | N.A. | N.A. |
| | | N.A. | N.A. | N.A. |
| | | N.A. | N.A. | N.A. |
| | | N.A. | N.A. | N.A. |
| | | N.A. | N.A. | N.A. |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | -- | -- | -- |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

DCFO (WZ)

Signature of the Inspecting Officer

Name

Designation

Signature
12/9/13
DO(NW)

