

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001
Ph.23414333, Fax: 23412593, E-mail:cfohq.dlfire@nic.in

No. *FG/DFS/MS/EH/2013/MDZ/982*

Dated: *27/09/13*

FIRE SAFETY CERTIFICATE

Certified that the banquet in the name & style Tarang Banquet Hall at Ground floor of the building comprised of basement, ground plus two upper floors at A-9/136, Road No.56, Gazipur Village, Delhi-96, owned/occupied by M/s Tarang Gardens and Banquets Pvt.Limited have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 16.09.13 in the presence of Sh.Vijay Malik(Director) that the building is fit for occupancy Group -D (Assembly building) with effect from *27.09/13* for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf

Issued on.....*27/09/13*.....at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
Delhi Fire Service

*Dr
27/09/13*

To,
The Dy.Health Officer
East Delhi Municipal Corporation
Health Department, Karkardooma
South Zone, Shahdara, Delhi.

Copy to:-
M/s Tarang Gardens and Banquets Pvt.Limited
A-9/136, Road No.56, Gazipur Village, Delhi-96

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction/ unauthorized use of land if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: Tarang Banquet Hall at A-9/136, Road No.56, Gazipur Village, Delhi-96.
 2. Building Comprised of : Basement ground plus two upper floors
 3. Type of Occupancy : Assembly
 4. Type of Case : New
 5. Details of Previous NOC : -----
 6. Fire Safety directives No : F.6/DFS/MS/BP/2013/2135 dated 02.09.13
 7. Date of Inspection : 16.09.13
 8. Name of the Inspecting Officer : DO Virendra Singh
 9. Name of the designation of Officer
 From the building side : Sh.Vijay Malik (Director)
 10. Year of Construction : 2008
 11. Applicant's letter No : 07.09.13

	Minimum Standards on fire prevention and fire safety U/R33	NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	12 Mtrs	40 Mtrs.	MR
	• Gate width	4.5 Mtrs.	4.5 Mtrs.	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	2 Nos.	2 Nos.	MR
	• Upper Floor	2 Nos.	2 Nos.	MR
	• Basement	2 Nos.	2 Nos.	MR
	B. Width of Staircases	1.5 M	1.5 M & 1.15 M	MR
	• Upper Floor	1.5 M	1.5 M & 1.15 M	MR
	• Basement	1.5 M	1.5 M & 1.15 M	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	1 No.	1 No.	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	2.0 Mtr.	3 nos. of 2.0M	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	Required	Exhaust Fan Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguisher			
	• Total numbers	08 nos.	10 Nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR

Tarang Banquet Hall , A-9/136, Road No.56, Gazipur Village, Delhi-96.

6	First-aid-Hose Reels.			
	• Total numbers of each floor	1 no.	1 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Heat/Smoke	Heat/Smoke	MR
	• Location of main panel	Required	Provided at reception	MR
	• Location of repeater panel	Required	Provided	MR
	• Alternate source of power	Required	D.G.Set	MR
	• Hooters's location	Required	Strategic Locations	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	Not Required	provided	Acceptable
10	Automatic Sprinkler System.			
	• basement	Required	Provided	MR
	• upper floors	N/A	Provided	Acceptable
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose Box	01 no.	01 no.	MR
12	Yard Hydrants.	N/A	N/A	N/A
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.	N/A	N/A	N/A
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	1620 LPM	1620 LPM & 450 LPM	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Electricity	MR
	➤ Auto Starting of pump	Required	Auto	MR

1KN-5

14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	20000 Ltrs.	20000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	D.G.Set	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	Required	HT & LT panel protected with local application i.e Co2 fire extinguishers	MR

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer
 Name VIRENDRA SINGH
 Designation DOLE

Dy CFO (NDZ)

