

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001.**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No. F.6/DFS/MS/EH/2013/ 52/1001

Dated: 30/9/2013

FIRE SAFETY CERTIFICATE

Certified that the **Dimple Restaurant** located at 2105, D.B. Gupta Road, Karol Bagh, New Delhi-110005. The restaurant is established at ground floor of a three storied building comprised of basement, ground floor plus two upper floors. The restaurant having two exits was issued NOC by this department vide letter F.6/DFS/MS/EH/2010/1977 dated 05.07.2010 owned/occupied by the management of above said restaurant. The Restaurant building was re-inspected by the officer concerned of this department on 20.09.2013 in the presence of Sh. Arvind Singh (Manager) and found that the management have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (Ground floor only) is fit for occupancy class Group D assembly building Sub- Division D-6 w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....30/09/2013.....at New Delhi.

(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

- 1 The Manager,
Dimple Restaurant, 2105, D.B.G Rd.,
Karol Bagh, New Delhi-110005.

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provisions of the Building Bye Laws, 1983.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

The building is comprised of basement, Ground floor plus two upper floors.
 The restaurant is running at Ground floor only with two exits.

N/A.

INSPECTION REPORT

1. Name & address of the building :	Dimple Restaurant, 2105, D.B.G. Rd, Karel Bagh,			
2. Type of Occupancy :	Group D (Restaurant) N.O. - OS.			
3. Type of Case :	New Case/Renewal			
4. Details of Previous NOC :	Letter No. F.G/DFS/MS/EH/2010/1977 Date 05.07.2010			
5. Fire Safety directives letter No :	-			
6. Date of inspection :	20.09.2013			
7. Name of Inspecting Officer :	A.D.O P.S. Dabirya			
8. Name and designation of officers From the building side :	Sh. Arvind Singh (Manager)			
9. Year of Construction :	Before 2005			
10. Applicant's letter No. :	Nil dated 19.06.2013			
S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks
1.	Access to building			MR/NMR
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible ✓ -	18 mtr 90cms Each -	MR MR (02 Gates)
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	- Two	- Two	Rest. running at G.F only MR
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	- -	- 115cms, 130cms	Rest. running at G.F only MR, Being a old case.
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door pressurization 	- -	- -	- -
	d. No. of continuous staircases to terrace			
	e. Width of Corridor			
	f. Door Size			Rest. running at G.F only
			95cms x 200cms	-
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	- - - - -	- Sealed - -	- - - -
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors / Ground Floor 	30 a/c per hour	Exhaust Fans are provided - do -	MR MR

		12 a/c per hour		
5.	Fire Extinguishers			
	• Total numbers	06 Nos	Provided	MR
	• Types	CO ₂ , WCO ₂	- do -	MR
	• IS marking	ISI marked	ISI Marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on ^{Ground} each floor	One	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	D-G Set of 82.5 KVA	-
	• Hooters' Location	-	-	-
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	-	-	-
	• Number of hydrants per floor	-	-	-
	• Hose Box	-	-	-
12.	Yard Hydrants			
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-

N/9. 2105, D.B.G Road, Karol Bagh,
New Delhi - 110005.

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	<p>—</p> <p>450 LPM</p> <p>30 M</p> <p>Required</p>	<p>—</p> <p>450 LPM</p> <p>30 M</p> <p>Provided</p>	<p>—</p> <p>MR</p> <p>MR</p> <p>MR</p>
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>Provided</p> <p>—</p> <p>5000 Ltr</p>	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>MR, Being an Old Case</p>
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts:			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>	<p>No Lift</p> <p>-do-</p> <p>-do-</p> <p>-do-</p> <p>-do-</p>
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	<p>—</p> <p>—</p>	<p>—</p> <p>—</p>	<p>—</p> <p>—</p>
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	<p>—</p> <p>—</p> <p>—</p> <p>Required</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p> <p>Provided</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p> <p>MR</p> <p>—</p>
20.	Special Fire Protection System for Protection of special Risks, if any:	—	—	—

N/10-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to ^{Renewal} grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~



P.S. Dahiya
27/9/13

Signature of Inspecting Officer

Name *P.S. Dahiya*

Designation *Asstt. Divisional Officer*

Signature of Inspecting Officer

Name

Designation