

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Email:- cfohq.dlfire@nic.in

Ph. No. 23414333

No. F.6/DAS/MS/BN&T/2013/NDZ/999

Dated 30/9/13

FIRE SAFETY CERTIFICATE

Certified that the Golden Moment Party Place, at 870, East Park Road, Karol Bagh, New Delhi comprised ground floor having two party halls, office, kitchen and stores was inspected by the officer concerned of this department on 24/09/2013 in the presence of Mr. Subodh Bawa and found that the said party halls building have complied with the prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and the building is fit for occupancy class D (a) (ii) "Assembly Building" with effect from 30/09/2013 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued on 30/09/13..... at New Delhi by.



(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service

Copy to :-

- (1). The Medical Officer of health, New Delhi Municipal Council, Health Department Parliament Street, New Delhi w.r.t. letter no. DHO/KBZ/2013/567 dated 05/08/2013.
- (2). Golden Moments Party Place, at 870, East Park Road, Karol Bagh, New Delhi.

Condition for the validity of fire safety certificate:-

1. All the fire safety arrangements provided there in shall be maintained in good working conditions at all times. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

n/b

INSPECTION REPORT

1. Name & address of the building : Golden Moments, Party Place at 870, East Park Road, Karol Bagh,
New Delhi - 110005
2. Type of Occupancy : **Assembly**
3. Type of Case : New Case
4. Details of previous NOC : NA
- 5 Fire Safety directives Letter No. : No. F6/DFS/MS/BP/2013/2032 dated 16/08/2013
- 6 Date of inspection : 24/09/2013
- 7 Name of the Inspecting Officer : **DY CFO NDZ. & ADO M.K.Sharma**
- 8 Name and designation of Officer
from the building side : Mr. Subodth Bawa
- 9 Year of Construction : 2003
10. Applicant's letter No. : DHO/ KBZ/ 2013/567 dt New Delhi 05/08/2013

Ground Floor

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site (PSS Area)	Remarks MR/NMR (P.S.S Area)
1.	Access of building			
	• Road width	9 mt	17 mt	MR
	• Gate width	4.5 mt	4.5 mt	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	NA	NA	NA
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases	NA	NA	NA
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c..Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA

Mesh

2/4

2/4

	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2 mt	2.4 mt	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	30 ACPH	NA	NA
	• Upper floors	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	• Total numbers	10	10	MR
	• Types	ABC 4, Wco ₂ 6	ABC, Wco ₂	MR
	• IS marking	ISI marked	YES	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	03	03	MR
	• Length of hose reel hose	30 mt	30 mt	MR
	• Nozzle diameter	05 mm	05 mm	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	MR	P	MR
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor			
	• Sprinkler above false ceiling	NA	NA	NA

N/S

		NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down- comer	150	150	MR
	• Number of hydrants per floor	01	P	MR
	• Hose Box	01	P	MR
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements			
	○ Ground Level	NA	NA	NA
	• Discharge of main pump	900	900	MR
	• Head of main pump	30 mt	P	MR
	• Number of main pumps	NA	NA	NA
	• Jockey pump out put	NA	NA	NA
	• Jockey pump head	NA	NA	NA
	• Standby Pump out put	NA	NA	NA
	• Standby Pump Head	NA	NA	NA
	• auto Staring/Manual stopping	NA	NA	NA
	• Pump House Access	NA	NA	NA
	○ Terrace level	NA	NA	NA
	• Discharge of pump	NA	NA	NA
	• Head of the pump	NA	NA	NA
	• Power supply	YES	P	MR
	• Auto starting of pump	NA	NA	NA
14	Captive water Storage for fire fighting	NA	NA	NA
	• Under ground tank capacity	NR	20000 NR	MR NA
	• Draw of connection	NA	NA	NA
	• Fire service inlet	NA	NA	NA
	• Access to tank	YES	P	MR
	• Overhead Tank capacity	15,000	15000+20000	MR

Handwritten signature and arrow pointing to the table.


Handwritten signature.

N/6

15	Exit Signage	YES	P	MR
16	Provision of Lifts			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of lift lobby	NA	NA	NA
	• Communication in lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	YES	D.G Set	MR
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NR	P	MR
20	Special Fire Protection Systems for Protection of special Risks, if any;	YES	ABC,	MR

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule it is recommended to grant fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / for the M/S golden moments party hall.



Dy CFS / NDZ.

(Handwritten signature)

(Handwritten signature)
24/9/13

Signature of the Inspecting Officer

Name :- M.K. Sharma
Designation :- A. D.O. (CC)