

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

Fax : 23412593, E-mail: cfohq. dlfire@nic.in Tel :- 011-23414333


No: F6/DFS/MS/2013/school/N021990

Dated: 30/09/13

FIRE SAFETY CERTIFICATE

Certified that the Savitri Pratap Singh Block at Raghubir Singh Junior Modern School, Humayun Road, New Delhi-110003 comprised of ground plus two upper floors was granted NOC by this department vide letter No. F6/DFS/MS/93/2041 dated 13-12-93 The premises was re-inspected by the officer concerned of this department on 17-09-2013 in the presence of Commander (Retd.) Sh. D.K.Singh and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of class B "Educational Building" with effect from-----30/09/13-----for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions rule 38 of the Delhi Fire Service Rules, 2010.

Issued 30/09/13... at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service



Copy to :-

1. Mrs. Manju Rajput, Headmistress, Raghubir Singh Junior Modern School, Humayun Road, New Delhi-110003
2. The Director Education, Old Secretariat, Delhi 110054

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

Savitri Pratap Singh Block at Raghubir Singh Junior Modern School, Humayun Road, New Delhi

INSPECTION REPORT

1. Name & address of the building : Savitri Pratap Singh Block at Raghubir Singh Junior Modern School, Humayun Road, New Delhi-110003
2. Type of Occupancy : Educational (School) **GF + 02 upper floors.**
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/93/2041 dated 13-12-93
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 17-09-2013
7. Name of the Inspecting Officer : Sh. Manoj Sharma (A.D.O.) and Sh. D.S. Yadav (D.O.)
8. Name and designation of Officer from the building side : Sh. Mr. Commander D.K. Singh
9. Year of Construction : 1993
10. Applicant's letter No. : BT/RSJMS/FFS/01 Dated 12-07-2013

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	06 mtrs.	MR
	• Gate width	N/A	6.22 mtrs	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01	01	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	150cms.	150 cms.	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	01	01	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	N/A	N/A	N/A
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Natural ventilation	MR

Savitri Pratap Singh Block at Raghubir Singh Junior Modern School, Humayun Road, New Delhi

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	08 ISI marked	08 Water Co2 & A.B.C. type. Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	N/A 30 M 5 mm	N/A N/A N/A	N/A N/A N/A
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8.	MOEFA/Siren	Required	provided	MR
9.	Public Address System	Required	provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ auto Staring/Manual stopping ➤ Pump House Access Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A 450 LPM 35 Mtrs. Required Required	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A Provided Provided. Provided Provided	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A MR MR M/R M/R
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	N/A N/A N/A N/A 5000 Ltrs.	N/A N/A N/A N/A Provided.	N/A N/A N/A N/A MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A

Savitri Pratap Singh Block at Raghbir Singh Junior Modern School, Humayun Road, New Delhi

	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer

Name
Designation

Signature of the Inspecting Officer

Name
Designation