

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

Ph.23414333,Fax:23412593,E-mail:cfohq.dlfire@nic.in

No. *f6/DFS/MS/2013/N02/1011*

Dated: *03/10/13*

FIRE SAFETY CERTIFICATE

Certified that the Storage of petroleum Class A& B at Kargil Heights Filling Station, Vasundhara Enclave, Kondli Road, Chilla Sports Complex (DDA), Delhi, owned/occupied by M/s Kargil Heights Filling Station comprised of ground floor was granted NOC vide letter no. No.F.5/(3A)/DFS//2001/42 dated 05.07.2005. The Filling Station was inspected by the officer concerned of this department on 19.02.13 in the presence of Sh.Ajay Kumar (Manager) and found that the Filling Station have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and that the Filling Station is fit for occupancy Storage of petroleum Class A& B (A-20 KL & B-40 KL), with effect from *03/10/13*..... for a period of three years, subject to conditions printed overleaf.

Issued on *03/10/13*..... at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
Delhi Fire Service

*Dr
26/9/13*

To,
M/s Kargil Heights Filling Station,
Vasundhara Enclave, Kondli Road,
Chilla Sports Complex(DDA), Delhi

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction/ unauthorized use of land if any.
7. Safety distance shall always be kept free from any storage of combustible material and shall be provided within the licensed premises .
8. Nothing in contravention of the Petroleum Act and Rules 1976 as modified (especially Chapter-V Rule 117) from time to time. All comments/ directions of the Chief Inspector of Explosives should always be permitted and followed.