

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/AH/2013/W2/1008 Dated: 01/10/2013

FIRE SAFETY CERTIFICATE

Certified that the Surya Garden, located at, Palla Bakhtawar Pur Road comprised of Basement + Ground floor is built on a plot area of 2.5 acre land with covered area of approximately 125 square yard is owned / occupied by Sh Vipin Girdhar, have complied with the fire prevention and fire safety Requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on 21/09/2013 in the presence of Sh Vipin Girdhar, and that the building / premises is fit for occupancy Class Sub Div. D-5 Assembly Buildings with effect 01 / 10 /2013 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

1. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
2. The fire suppression / protection arrangements provided are to minimize losses, if maintained in good working condition. These systems cannot give a guarantee that there will be no fire or losses in the event of one.
3. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
4. This report may not in any way be treated as regularization of unauthorized construction, if any. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. The trained fire fighting staff should be available round the clock.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 01 / 10 /2013 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
cfowz.dlfire@nic.in

Copy to:

1. The Executive Engineer (Building), Municipal Corporation of Delhi, Narela Zone, Zonal Office Building, Narela, Delhi, with reference to the letter No AC/NRZ/2013/490 dated 05/02/2013, *nbc is valid for function of 300 persons only.*
2. Sh Vipin Girdhar, Surya Garden, Palla Bakhtawar Pur Road

May kindly see the letter No AC/NRZ/2013/490 dated 05/02 /2013 received from Assistant Commissioner (MCD), Narela Zone and compliance of recommendations communicated vide this office letter No F-6/DFS/MS/BP/2013 dated 14/08/2013 and subsequent compliance report dated nil received in this office vide ODD 9380 dated 29/08/2013 regarding issuance of NOC from fire safety and fire prevention point of view in respect of Surya Garden located at Palla Bakhtawar Pur Road, Delhi for holding social function such as wedding and parties etc.

Accordingly the farm house premise was visited and inspected by the undersigned along with Sh Vipin Girdhar on dated 21/09/2013 as per Delhi Fire Service Act, 2007 and Delhi Fire Service Rules, 2010 and it was observed that the farm house is comprised of Basement + Ground floor having a total plot area of approx 2.5 acre. The permanent structure covers approximately 125 sq yards.

Remaining portion is open green, temporary shed, parking and road etc. No permanent sitting arrangement was seen at the time of inspection. The premise is approachable from Palla Bakhtawarpur main road of **82** feet.

**As regards to the fire protection arrangements, the status is as under.**

S/NO.	Fire Safety Provision	Provided / Not Provided
1.	Access to building	Accessible & NOC already issued by team.
2.	Number, width type and arrangement of exits	<b>125 to 127 cms by peeling wall and removing the railing.</b>
3.	Protection of exits by means of fire checks door (s) and or pressurization.	—
4.	Compartmentation	—
5.	Smoke Managements system	Exhaust fan Provided
6.	Fire Extinguishers	18 ABC type & functional
7.	Fire Aid Hose Reels	Provided & functional
8.	Automatic Fire detection and alarming system	—
9.	MOEFA	Provided & functional
10.	Public Address System	N/A
11.	Automatic sprinkler system	Provided in side wall
12.	Internal Hydrants and Yard Hydrants	Provided & functional
13.	Pumping Arrangements 450 LPM	450 LPM
14.	Captive water Storage for fire 10000 ltr	10000 ltr ( <b>Valid for function of 300 persons</b> )
15.	Exits Signage	Provided
16.	Provision of lifts	—
17.	Standby power supply	taken on rent at the time of function
18.	Refuge Area	—
19.	Fire Control Room	—
20.	Special fire protection systems for protection of special risks	—

