


NO.F6/DFS/MS/School/2013/SZ/ 1015

DATED: 03/10/13

FIRE SAFETY CERTIFICATE

Certified that the New Ring Midways Public School at E-109, Nanhey Park, Uttam Nagar, New Delhi-110059 comprised of ground plus two upper floors owned/occupied by New Ring Midways Public School. The inspection of school was carried out & found complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Gove of NCT of Delhi and verified by the officers concerned of Fire Service on 28.09.2013 in the presence of Mr. Mahesh Solanki (Manager), and that the building is fit for occupancy class B "Educational building" with effect from...03/10/13... for a period of **three** years, subject to condition as mentioned below.

Issued on ...03/10/13..... at New Delhi by



(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service



Copy to,

1. The Principal, New Ring Midways Public School at E-109, Nanhey Park, Uttam Nagar, New Delhi-110059.
2. The Director (Edu.), SDMC, 23rd floor, Civic Centre, Minto Road, New Delhi.

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	New Ring Midways Public School at E-109, Nanhey Park, Uttam Nagar, New Delhi-110059		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	New		
4	Details of previous NOC	No.		
5	Fire safety directives letter No	Edu. Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	28.09.2013		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Mahesh Solanki (Manager)		
9	Year of construction			
10	Applicant's letter No.	Nil Dated 30.08.2013	(Ground plus two upper floor)	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Edu. Circular/NBC Requirement	Provided at site	Remarks MR / NMR
--------	---	-------------------------------	------------------	------------------

1	Access to building			
	1) Road width	Required	6 Mtr Provided	MR
	2) Gate width	Required	3 & 1.75 Mtrs Provided	MR
	3) Width of internal road	N/A	N/A	N/A

2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos	2 Nos. Provided	MR ✓
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.25 Mtr	1.25 Mtr each Provided	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	One Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	Required	1 Mtr Provided	MR

3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Natural Vent.	MR

5	Fire Extinguishers			
----------	---------------------------	--	--	--

6	First-Aid Hose Reels.			
	total numbers on each floor	One	Provided	MR
	Length of Hose reel hose	30 Mtr	Provided	MR
	Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	MR
9	Public Address System.	Required	Provided	
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 LPM	Provided	MR
	b. head of the pump	Required	35 Mtr Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10,000 Ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	N/A		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/

Accordingly DFA is put up for your approval and signature please.


Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)