

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
Fax: 23412593, Email: cfohq.dlfire@nic.in Tel: - 01-23414333

NO. F6/DFS/MS/GH/2013/ND2/1017

Dated: 03/10/13

FIRE SAFETY CERTIFICATE

Certified that Singh Guest House, 3413-14, Behind Hamdard Dawakhana, Angoori Ghatta, Ajmeri Gate, Delhi-6 comprised of lower ground floor (Commercial use) upper ground floor (Commercial use), first floor (04 rooms), Second floor ((04 rooms), third floor (06 rooms), and terrace (Mumty + Water tank + DG set room) Total 14 rooms, was granted NOC by this department vide letter No. F.6/MS/DFS/GH/10/624 dated 04-03-2010. The premises was re-inspected by the officer concerned of this department on 19-09-2013 in the presence of Sh. Naresh Kumar, of the guest house and found that the said guest house is located in special area have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy of 14 guest rooms with effect from 03/10/13 for a period of ~~--03--~~ years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on 03/10/13 at New Delhi by.



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Addl.C.P (Lic.), Police Station, Defence Colony, 1st floor, New Delhi.
2. M/s Singh Guest House, 3413-14, Behind Hamdard Dawakhana, Angoori Ghatta, Ajmeri Gate, Delhi-6

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time.
- b. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- c. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- d. The trained fire fighting staff shall be available round the clock.
- e. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: Singh Guest House, 3413-14, Behind Hamdard
Dwarkhana, Angoori Ghatta, Ajmeri Gate, Delhi-6
2. Type of Occupancy : Lodging House
3. Type of Case : Renewal
4. Details of previous NOC : Letter No F-6/TMS/DFS/GH/10/624 dated 04-03-2010
5. Fire Safety directives Letter No. : NIL
6. Date of inspection : 19-09-2013
7. Name of the Inspecting Officer : Sanjay Kumar Tomar, A.D.O (SPM)
8. Name and designation of Officer SR. Naresh Kumar
 from the building side
9. Year of Construction : Started in 2010
10. Applicant's letter No. : 70872/Addl.C.P./LIC(H) dated 17/12/12

Spl. Area

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Motorable	Emf Provided	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	One	One	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	80 cms	94 to 100 cms	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	One	One Provided	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size			

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		N/A	
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour		
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	N/A	A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	6 nos ABC, wCO ₂ , CO ₂ ISI marked	Provided Six nos	MR
			Provided	MR
			Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	One	01 Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 mtr	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		N/A	A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 			
	<ul style="list-style-type: none"> • Upper Floor 		N/A	A

	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 		N	A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 		N	A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual stopping ➤ Pump House Access 		N	A
	<ul style="list-style-type: none"> • Terrace level 			
	➤ Discharge of pump	225 LPM	Provided	MR
	➤ Head of the pump	40 M	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	N/A	Switch Provided	MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 		N	A
		2500 ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR

Singh Guest House, 3413-14 Behind Hamdard, Angoori Ghatta, Ajmeri Gali

	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 							
17.	Standby power supply	Not Required	Emergency Light Provided					MR
18.	Refuge Area							
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 							
19.	Fire control room							
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Batter backup ➤ Building Floor Plans 							
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 fire extinguisher Provided near Electrical Panel					MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue ~~shortcomings as noted at serial numbers~~

2743

1114

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation

Dirn. Officer