

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001**

Fax: 23412593 E-mail:cfohq.dlfire@nic.in

No *F6/DFS/MS/School/2013/N02/1022* Dated *04/10/13*

FIRE SAFETY CERTIFICATE

Certified that the Nabarun Vidyapeeth Durgabari J-87, Laxmi Nagar, Delhi. comprises of ground floor was granted NOC by this deptt. vide letter No. F6 / DFS / MS / 2006/ 2421 dated 11- 09- 2006. The premises was re-inspected by the officer concerned of this department on 06-09-2013 in the presence of Mrs. Geetashi Bose (H.M.) and found that the School have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education and that the building is fit for occupancy class B "Educational Building" with effect from *4-10-2013* for a period of three year, subject to conditions printed overleaf.

Issued on *04/10/13* at New Delhi.



(DR.G.C.MISRA)
Chief Fire Officer
Delhi Fire Service
Ph. 23414333

Copy to:-

1. The Head Mistress
Nabarun Vidyapeeth Durgabari J-87,
Laxmi Nagar, Delhi.
2. The Director Education,
Government of N.C.T Delhi.
Old Sectt, Delhi 110054



11/2

INSPECTION REPORT

1. Name & address of the building: Nabarun Vidyapeeth Durgabari J-87,
Laxmi Nagar, Delhi.
2. Building is comprised of : Ground floor
3. Type of Occupancy : Educational.
4. Type of Case : Renewal
5. Details of Previous NOC letter: F6/MS/DFS/2006/2421 dated
11.09.2006
6. Fire Safety direction letter No : NA
7. Date of Inspection : 06-09-2013
8. Name of the Inspecting officers: Gurmukh Singh ADO (LN)
9. Name and designation of Officer: Mrs. Geetashi Bose (H.M.)
from the building side
10. Year of Construction : 1977
11. Applicant's letter No : dated 02-07-2013

S.N O.	Minimum Standards on fire prevention and fire safety U/R33	Director Education /Existing	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	15 ft	MR
	• Gate width	NA	Directly Accessable from road	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits	NA		
	a. Number of Staircases	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Basement	NA	NA	NA
	B. Width of Staircases	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Basement	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	g. Width of Corridor	1.2Mtr	1.2Mtr	MR
	h. Door Size	1.0 mtr wide	1.0 mtr wide	MR

h

W

11/3-

3	Compartmentation.	NA		
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire rating of shaft door	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.	NA		
	• Basement	NA	NA	NA
	• Upper floor	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	1 No.	1 No.	MR
	• types	ABC	ABC	MR
	• ISI marking	Required	Provided	MR
6	First-aid-Hose Reels.	NA		
	• Total numbers at ground floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system.	NA		
	• Type of detectors	NA	NA	NA
	• Location of main panel	NA	NA	NA
	• Location of repeater panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	Hooter's location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public address System.	NA	NA	NA
10	Automatic Sprinkler System.	NA	NA	NA
	• Basement	NA	NA	NA
	• upper floor	NA	NA	NA
	• sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants	NA	NA	NA
	• size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.	NA	NA	NA
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.	NA	NA	NA
	• Ground Level	NA	NA	NA

→/4-

Habqann Vidhyapeeth Durgabasi, J-87
Kaxmi Ngr, Delhi

	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main Pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting /Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace Level	NA	NA	NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the Pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for Fire Fighting.	NA	NA	NA
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.	NA	NA	NA
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication in lift car	NA	NA	NA
	• Firemen's grounding switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.	NA	NA	NA
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire Control Room	NA	NA	NA
	• Detector system panel	NA	NA	NA
	• Flow switch panel	NA	NA	NA
	• PA system panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA

h

-H/5-

20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	NA
----	--	----	----	----

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the Circular of Director Education, GNCTD in the light of office order No. F2/DFS/HQRS/300 dated 18-04-2012 it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Gurmukh Singh
6/9/13

Name - Gurmukh Singh

Designation ADO (LN)

Do(E)

Submitted for approval please.

Dy CFO (NDZ)

Vinod
9/01/13

THE SER...