

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/EH/2013/W2/1041

Dated: 08/10/2013

FIRE SAFETY CERTIFICATE

Certified that M/s Gola North End Restaurant located at plot No-3, LSC, Gujrawala Town, Delhi 110009 was granted NOC by this department vide letter no F-6 / DFS / MS / EH / 2010 / 2641 Dated 09/09/2010. The premises was re-inspected by the officers concerned of this department on 13 / 09 / 2013 in the presence of Sh. S P Singh, (Manager) and Sh Ashok Kapoor and found that the building have deem complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit for Assembly occupancy with effect from 08 / 10 / 2013 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of Delhi Fire Service Rules, 2010.


1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the restaurant are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 08/10/13 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
[cfowz.dlfire@nic.in](mailto:cfowz.dlfire@nic.in)

Copy to:

1. The Dy Health Officer, North Delhi Municipal Corporation, Health Department, Civil Lines Zone, 16, Rajpur Road, Delhi-54 for information w r t letter No DHO/CLZ/2013/943 dated 16/08/2013
2. The authorized signatory, Smt Meenakshi Kapoor, M/s Gola North End Restaurant located at-plot No -3, LSC, Gujrawala Town, Delhi 110009



(B+F+3)

**INSPECTION REPORT**

1. Name & address of the building : M/S Gola North End Restaurant PNo-3, LSC Gujrawala
2. Type of Occupancy : Restaurant
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DFS/MS/EH/2010/2641 Dated 09/09/2010.
5. Fire Safety directives letter No :
6. Date of inspection : 13/09/2013
7. Name of the Inspecting Officers : DCFO (WZ) & DO (NW)
8. Name and designation of officers  
from the building side : Sh. Ashok Kapoor & Sh. S.P Singh
9. Year of Construction : 2006
10. Applicant's letter No. : DHO/CLZ/2013/943 Dated 16/08/2013.

	<b>Minimum Standards on fire prevention and fire safety U/R 33</b>	<b>NBC Requirement</b>	<b>Provided at site</b>	<b>Remarks MR/NMR</b>
1	<b>Access to building</b>			
	• Road width	Accessible	✓ Accessible	✓ M/R
	• Gate width	-----	-----	-----
	• Width of internal road	-----	-----	-----
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02 ✓	02 ✓	M/R
	• Basements	01	01 ✓	M/R
	b. Width of staircases			
	• Upper Floors	Old case	Old case ✓	M/R
	• Basements	Old case	Old case ✓	M/R
	c. Protection of exits			
	• Fire check door	-----	-----	-----

	<ul style="list-style-type: none"> <li>• Pressurization</li> </ul>	----	----	----
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	----	----	----
	h. Door Size	----	----	----
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	---	-----	----
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	---	-----	----
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	---	-----	----
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour	Natural/ Exhaust	M/R
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour	---	-----
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	14 ABC Type	14	M/R
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ISI marked	08 ABC, 3 co2, 3 wco2	M/R
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>		Yes	M/R
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	one	Provided	M/R
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30 m	P	M/R
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5 mm	P	M/R
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	N.A	N.A	N.A
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	---	-----	----

	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	----	----	----
8	<b>MOEFA</b>	R	P	M/R
9	<b>Public Address System.</b>	R	P	M/R
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	R	P	M/R
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	R	P	M/R
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	----	----	----
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	04"	P	M/R
	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>	01	P	M/R
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	01	P	M/R
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> </ul>	01	P	M/R
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	01	P	M/R
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>• Ground Level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Head of Main pump</li> </ul>	----	----	----
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	----	----	----
	<ul style="list-style-type: none"> <li>➤ Jockey Pump out put</li> </ul>	180 LPM	P	M/R
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	40 M	P	M/R
		----	----	----

	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	----	----	----
		----	----	----
		----	----	----
		450 LPM	P	M/R
		40 m	P	M/R
		R	P	M/R
		R	P	M/R
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
		----	----	----
		----	----	----
		----	----	----
		5000 ltr	5000 ltr	M/R
15	<b>Exit Signage.</b>			
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
		----	----	----
		----	----	----
		----	----	----
		----	----	----

17	<b>Standby power supply</b>	R	P (1) 62 KVA (2) 125 KVA	M/R
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	----	-----	----
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	—	—	—
	• Battery backup			
	• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:	----	-----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers..... NIL .....

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation

*[Handwritten Signature]*  
16/9/13  
DD(NW)