

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

Fax : 011-23412593 E-mail : cfhq.dfire@nic.in Ph. 011-23414333.

No.F6/DFS/MS/School/2013/SZ/1044

Dated: 08/10/13

FIRE SAFETY CERTIFICATE

Certified that the **N.P.Primary School No-3 & 4** located at **Babu Market, Sarojini Nagar, New Delhi**, comprised of **Ground + 1 Upper Floor** was granted NOC by this department vide letter No.F6/DFS/MS/2010/2769 dated **22/09/10** was re-inspected & found complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire/Safety/ 2011/3298 to 3398 dated 01/03/11 issued by Directorate of Education, Govt. of NCT of Delhi and verified by the officer concerned of Fire Service on **30/09/13** in the presence of **Mr. Sajjan Kumar (Asstt. Fire Officer)** and that the building / premises is fit for occupancy class **Group 'B' Education Building** with effect from 08/10/13-----for a period of Three years subject to condition as mentioned below.

Issued on 08/10/13----- at New Delhi by.



(Dr.G.C.Misra)
Chief Fire Officer
Delhi Fire Service

Copy to:- (1) N.P. Primary School No. 3 & 4,
Babu Market, Sarojini Nagar, New Delhi.

(2) Director of Education,
Old Secretariat, Delhi.

Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protections measures shall be maintained in perfect conditions all the time as seen during inspection.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be the risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. the form is available on www.dfs.delhigovt.nic.in

N/3
INSPECTION REPORT

1. Name & address of the building:- N.P. Primary School No. 3 & 4, Babu Market, Sarojini Nagar, New Delhi.
2. Type of occupancy:- Group – B Education Building.
3. Type of case:- Renewal.
4. Details of previous NOC:- No.F6/DFS/MS/2010/2769 dated 22/09/10.
5. Fire safety directives No.- N/A as per education circular
6. Date of inspection:- 30/09/13
7. Name of the inspecting officer:- A.D.O. S.S. Kaushik
8. Name & designation of officer:-
From the building side:- Mr. Sajjan Kumar (Asstt. Fire Officer)
9. Year of construction:- 1973.
10. Applicant's letter No:- Fire/2032 Dated 10/09/13 Ground + 1 Upper floors

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	As per Education Circular	Provided at site	Remarks MR/NMR	Old Case
1.	Access to Building				
	1) Road width	Approachable	Provided	MR	
	2) Gate width	Required	Provided	MR	
	3) Width of internal road	N/A	N/A	N/A	
2.	Number, Width Type & Arrangement of Exits				
	A. Number of staircases				
	1. Upper floors	5 Nos.	5 Nos.	MR	
	2. Basements	N/A	N/A	N/A	
	B. Width of staircase				
	1. Upper floors	Required	1.53 mtr. X 2, 82 cms. X 2, 1.18 mtr. & 1.40 mtr. ramp.	MR	
	2. Basements	N/A	N/A	N/A	
	C. Protection of exits				
	1. Fire check door	N/A	N/A	N/A	
	2. Pressurization	N/A	N/A	N/A	
	D. No. of continuous staircase to terrace				
		Yes	2 Nos.	MR	
	E. Width of corridor				
		N/A	N/A	N/A	
	F. Door size				
		1 mtr.	1 mtr.	MR	
3.	Compartmentation				
	1) Fire check door	N/A	N/A	N/A	
	2) Sealing of electrical shafts	N/A	N/A	N/A	
	3) Fire rating of shaft door	N/A	N/A	N/A	
	4) Water curtain	N/A	N/A	N/A	
	5) Fire Dampers	N/A	N/A	N/A	
4.	Smoke Management System				
	1) Basements	30 a/c per hour	N/A	N/A	
	2) Upper floors	12 a/c per hour	Open corridor	MR	
5.	Fire Extinguishers				
	1) Total numbers		14 Nos.	MR	
	2) Types		ABC & co2	MR	



14/4

	3) ISI marking	ISI Marked	Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	NR	3 Nos. at each floor	MR
	2) Length of hose reel hose	30 m	Provided	MR
	3) Nozzle diameter	5 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	NR lower GF	Provided ^{LG F}	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A

13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	NR	450 LPM	MR
	b) Head of pump	NR	40 mtr.	MR
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	NR	3,000 ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.	N/A	N/A	N/A

Mansky

	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A

	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renewal Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/-----

Accordingly DFA is put up please.

Signature of the inspecting officer


Signature of the inspecting officer

Name:-

Name:- S.S.Kaushik

Designation:-

Designation:- Assistant Divisional Officer



Do not work
11/10/13