


No. F.6/DFS/MS/EH/2013/SZ/ 1064

Dated: 10/10/13

**FIRE SAFETY CERTIFICATE**

Certified that the Moti Mahal Delux Restaurant at 20/48. Malcha Marg. Diplomatic Enclave New Delhi running at ground and mezzanine floor of the building comprised of basement ground plus two upper floors was granted NOC by this department vide letter No. F6/DFS/MS/EH/2010/760 dated 12.03.2010. The premises was re-inspected by the officer concerned of Delhi Fire Service on 27.09.2013 in the presence of Mr. Sanjeev of the restaurant and observed that fire safety norms as required under Rule 33 of Delhi Fire Service Rules, 2010 have deemed complied and that the building / premises is fit for occupancy class-D "Assembly building Restaurant" with effect from 10/10/13 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on 10/10/13..... at New Delhi by

  
(Dr. G.C. Misra)  
Chief Fire Officer  
Delhi Fire Service

ALP  
✓

Copy to: -

1. The DHO(South Zone), Office of Deputy Health Officer, M.C.D. Health Department South Zone, Green Park, New Delhi,
2. The Manager, Moti Mahal Delux Restaurant at 20/48. Malcha Marg. Diplomatic Enclave New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The Basement shall be used strictly as per the provisions of Building Bye Laws.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

1	Name & address of the building	Moti Mahal Delux Restaurant 20/48 Malcha Marg. Diplomatic Enclave New Delhi		
2	Type of Occupancy	Assambly "D"		
3	Type of case	Renewal		
4	Details of previous NOC	F6/MS/DFS/EH/2010/760 Dated 12.03.2010		
5	Fire safety directives letter No	Nil		
6	Date of inspection	27.09.2013		
7	Name of the inspecting Officers :	D.O. (South) D.P. Bhardwaj, ADO(BCP) S.S.Kaushik		
8	Name and designation of officers	Sh. Sanjeev		
	from the building side			
9	Year of construction	(Basement,Ground, plus two and upper floors)		
10	Applicant's letter No.	Nil	02.09.2013	(Resturant running at ground and Mezzanine floor)
<b>S. NO.</b>	<b>Minimum Standards on fire prevention and fire safety U/R 33</b>	<b>NBC Requirement</b>	<b>Provided at site</b>	<b>Remarks MR / NMR</b>
<b>1</b>	<b>Access to building</b>			
	1) Road width	6 mtrs	Provided	MR
	2) Gate width	N/A	N/A	MR
	3) Width of internal road	N/A	N/A	MR
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	Old Case	2 Nos Provided	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	Old Case	90 cm & 80 cm Provided	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Old Case	One	MR
	<b>e. Width of corridor</b>	N/A	N/A	MR
	<b>f. Door size</b>	Old Case	2 Nos. Provided	MR
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Exhust Fans Provided.	MR
<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers		8 Nos	MR
	Types		ABC, Water Co2	MR
	ISI marking	ISI	Yes	MR

<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	1 Nos.	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
<b>7</b>	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
<b>8</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9</b>	<b>Public Address System.</b>	N/A	N/A	N/A
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	Required	Provided	MR
	sprinkler above false ceiling	N/A	N/A	MR
<b>11</b>	<b>Internal Hydrants</b>			
	Size of riser/down-corner	100 MM	Provided	MR
	Number of Hydrants per floor	One	Provided	MR
	hose Box	One	Provided	MR
<b>12</b>	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	MR
	hose box	N/A	N/A	MR
<b>13</b>	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	MR
	b.Head of main pump	N/A	N/A	MR
	c.Number of main pumps	N/A	N/A	MR
	d.jockey pump out put	N/A	N/A	MR
	e.jockey pump head	N/A	N/A	MR
	f. Standby Pump output	N/A	N/A	MR
	g.Stanby Pump head	N/A	N/A	MR
	h.Auto Starting/Manual stopping	N/A	N/A	MR
	pump house access	N/A	N/A	MR
	<b>2.Terrace level</b>			
	a. Discharge of pump	450 LPM & 180 LPM	Provided	MR
	b. head of the pump	35 mtr	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
<b>14</b>	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	Provided	MR
	a. Draw-off connection	N/A	Provided	MR
	b. fire service inlet	N/A	Provided	MR
	c.Access to tank	N/A	Provided	MR
	Over head tank Capacity	5,000 ltr	Provided	MR
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16</b>	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	MR
	b. pressurization of lift lobby	N/A	N/A	MR

Standby power supply		Required	Provided	MR
18	<b>Refuge Area.</b>			
	total area	Not Required		
	location			
19	<b>Fire control room</b>			
	a. detector system Panel	N/A	N/A	MR
	b. Flow switch Panel	N/A	N/A	MR
	c. PA system Panel	N/A	N/A	MR
	d. Batter backup	N/A	N/A	MR
	e. Building floor plans	N/A	N/A	MR
20	<b>Special Fire Protection systems for protection of special risks, if any:</b>			MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule. The grant of Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/ May be recommended for the said restaurant subject to conditions given in the letter Accordingly DFA is put up for your approval and signature please.

Signature of the inspecting officer

Name D. P. Bhardwaj

Designation : Divisional Officer (South)

Signature of the Inspecting Officer

Name

S.S. Kaushik

Designation

ADO (BCP)