

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001
Fax:- 011-23412593


No F 6 / DFS / MS / GH / 2013 / N02 / 1076

Dated 15/10/13

FIRE SAFETY CERTIFICATE

Certified that the Restaurant in the name and style of The Billiardiers Restaurant located at H-26, Tropical building, Connaught Place, New Delhi - 110055 comprised of ground floor (Restaurant), mezzanine floor (storage), was granted NOC by this department vide letter No. F6/DFS/MS/EH/2011/933 dated 20-05-11. The premises was inspected by the officer concerned of this department on 07-09-2013 in the presence of Mr. Manish (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy with effect from 15/10/2013 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/10/13 at New Delhi by.



(Dr. G.C. Misra)

CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Tel:- 011-23414333

E-Mail:- cfohq.dfire@nic.in

Copy to:-

1. The Billiardiers Restaurant located at,
H-26, Tropical building, Connaught Place, New Delhi - 110055
2. Medical Officer of Health, Health Department, NDMC.
3. Addl. C.P. (Lic), Police Station, Defence Colony, New Delhi-110049

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

OK

OK

N/17

INSPECTION REPORT

1. Name & address of the building : The Billiardiers 26- H, Connaught Circus, New Delhi-110055
2. Type of Occupancy : Restaurant at G.floor
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2011/933 Dt 20/05/11
- 5 Fire Safety directives Letter No. : NA
- 6 Date of inspection : 07/09/2013
- 7 Name of the Inspecting Officer : M.K.Sharma (Assistant Divisional Officer)
- 8 Name and designation of Officer
from the building side : Mr.. Manish (Manager)
- 9 Year of Construction : Exitsiting structure (C.P.outer Circul)
10. Applicant's letter No. : Nill dt New Delhi 16/07/2013

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site (PSS Area)	Remarks MR/NMR (P.S.S Area)
1.	Access of building			
	• Road width	NA	30 Mt	MR
	• Gate width	1250	2000	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases	NA	NA	NA
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c..Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA

Manish

	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	30 ACPH	NA	NA
	• Upper floors	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	• Total numbers	09	P	MR
	• Types	Co ₂ , ABC, Wco ₂	P	MR
	• IS marking	YES	P	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	01	P	MR
	• Length of hose reel hose	30 Mt	P	MR
	• Nozzle diameter	05 mm	P	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NR	P	MR
9	Public Address System	NR	P	MR
10	Automatic Sprinkler System			
	• Basements	YES	P	MR
		NA	NA	NA

2/9

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down- comer 	NA	NA	NA
	<ul style="list-style-type: none"> • Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
12	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
13	Pumping Arrangements			
	<ul style="list-style-type: none"> ○ Ground Level 	NA	NA	NA
	<ul style="list-style-type: none"> • Discharge of main pump 	NA	NA	NA
	<ul style="list-style-type: none"> • Head of main pump 	NA	NA	NA
	<ul style="list-style-type: none"> • Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> • Jockey pump out put 	180	P	MR
	<ul style="list-style-type: none"> • Jockey pump head 	20 mt	P	MR
	<ul style="list-style-type: none"> • Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> • Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> • auto Starting/Manual stopping 	NA	NA	NA
	<ul style="list-style-type: none"> • Pump House Access 	NA	NA	NA
	<ul style="list-style-type: none"> ○ Terrace level 	NA	NA	NA
	<ul style="list-style-type: none"> • Discharge of pump 	450 LPM	P	MR
	<ul style="list-style-type: none"> • Head of the pump 	30 Mt	P	MR
	<ul style="list-style-type: none"> • Power supply 	R	P	MR
	<ul style="list-style-type: none"> • Auto starting of pump 	NA	NA	NA
		NA	NA	NA
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> • Draw of connection 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire service inlet 	NA	NA	NA
	<ul style="list-style-type: none"> • Access to tank 	YES	P	MR

MSH

N/10

	• Overhead Tank capacity	5000	P	MR
15	Exit Signage	R	P	MR
16	Provision of Lifts			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of lift lobby	NA	NA	NA
	• Communication in lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NR	P	MR
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	YES	ABC, Co ₂	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule it is recommended to grant fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 /

M.K. Sharma
8/7/13
Signature of the Inspecting Officer

Name :- M.K. Sharma
Designation :- A. D.O. (CC)

D.O. (CC)
submitted please