

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

C/9.

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No. F.6/DFS/MS/School/2013/52/1086

Dated: 25/10/13

FIRE SAFETY CERTIFICATE

Certified that the building of S. K. R Public School located at Bohrianwala Thalla, Inderpuri, New Delhi-110012 comprised of Basement/Lower ground, ground, floor plus three upper floors but the school is running at ground floor plus three upper floors only, having total 50 rooms (Including Class Rooms, Office, Staff Rooms, Labs, Library, Sports Room, Examination Room, Music Room & Store etc.) owned/occupied by the Goswami Sati Kewal Ram Ji (Bohrianwala) Memorial Society was re-inspected by the officer concerned of this department on 01.10.2013 in the presence of Smt. Uma Dwivedi (Principal) and found that the Goswami Sati Kewal Ram Ji (Bohrianwala) Memorial Society have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for (Ground floor plus three upper floors only) occupancy class Educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....15/10/2013.....at New Delhi.



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Principal,
S. K. R. Public School,
Bohrianwala Thalla, Inderpuri, N.D-12.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi – 110 054.



Basement/Lower Ground, Ground Floor plus three upper floors.
 School running at Ground Floor plus three upper floors.

M/9.

INSPECTION REPORT

1. Name & address of the building : S.K.R. Public School, Bohrianwala Thalla,
2. Type of Occupancy : Educational (School) Index Plan, N.D-12.
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. _____ Date _____
5. Fire Safety directives letter No : _____
6. Date of inspection : 01.10.2013
7. Name of Inspecting Officer : A.D.O P.S. Dahiya
8. Name and designation of officers
From the building side : Smt. Uma Dwivedi (Principal)
9. Year of Construction : 1990
10. Applicant's letter No. : Nil dated 08.08.2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks
1.	Access to building			MR/NMR
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible - -	06mtr 345cm -	MR MR -
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	Three One	Three One	MR (Old Bldg.) Not use for School purpose.
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	-	164, 85, 80 to 120cm	MR (Old Bldg.)
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • pressurization 	-	-	-
	d. No. of continuous staircases to terrace			
	-	-	One	-
	e. Width of Corridor			
	-	-	228 cm	-
	f. Door Size			
	-	-	109cm x 202cm 91cm x 199cm	-
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	-	Sealed	-
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	-	Not use for School purpose. Natural Ventilation MR

M/10

		12 a/c per hour		
5.	Fire Extinguishers			
	• Total numbers	Four at each floor	Provided	MR
	• Types	CO ₂ , WCO ₂ , ABC	- do -	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	-	-
	• Hooters' Location	-	-	-
8.	MOEFA			
9.	Public Address System			
			Provided	-
10.	Automatic Sprinkler System			
	• Basement	-	-	Not used for School purpose.
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	-	-	-
	• Number of hydrants per floor	-	-	-
	• Hose Box	-	-	-
12.	Yard Hydrants			
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-

Bohriawala Thalla, Indrapuri,
New Delhi - 110012.

M11.

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	-
		450LPM	450LPM	MR
		30M	30M	MR
		-	-	-
		-	-	-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	-	-	-
		-	-	-
		-	-	-
		-	-	-
		10000 ltr	10000 ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	No Lift
		-	-	- do -
		-	-	- do -
		-	-	- do -
		-	-	- do -
17.	Standby power supply	-	-	-
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	-	-	-
		-	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	-	-	-

N/12.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note:- The school building is comprised of Basement / Lower Ground, Ground Floor plus three upper floors. The basement / Lower Ground is not used for school purpose as per letter submitted by the manager of the school. There are total 50 Rooms including Office, Class rooms, Staff room, Labs, Library, Sports room, Examination room, Music room & Store etc. The school is running at Ground floor plus three upper floors. FSC is recommended for Ground floor plus three upper floors.


Signature of Inspecting Officer

Name P.S. Dahiya

Designation ~~ASST.~~ Divisional Officer

Signature of Inspecting Officer

Name

Designation

