

C-5

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DFS/ms/s/2013/w2/1083

Dated: 15/10/2013

**FIRE SAFETY CERTIFICATE**

Certified that the M C Primary School, B-2/ II & I, Sultan Puri, Delhi comprised of One block Ground Floor, Two block Ground + One Upper Floor each owned/occupied by M C Primary School, complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 30/09/2013 in the presence of Sh. Kailash Mandal (Principal) and that the building / premises is fit for occupancy of Educational building with effect from 15/10/2013 for a period of three years, subject to following conditions.

**Conditions for the validity of Fire Safety Certificate:**

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 The basement shall be used strictly as per the provision of building bye laws.
- 6 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 15/10/13 at New Delhi

  
15/10  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
cfowz.dlfire@nic.in

**Copy to:**

1. The Principal, M C Primary School, B-2/ II & I, Sultan Puri, Delhi-110086
2. The Addl. Director of Education, North MCD, Civic Centre New Delhi.



N/1

One - Block - G.F. only. Two blocks - G.F + one upper floor each.

**INSPECTION REPORT**

1. Name & address of the building: M.C. Primary School, B 2/IT&T
2. Type of Occupancy: Sultanpuri, Delhi-88, Educational
3. Type of Case:  New Case /  Renewal
4. Details of previous NOC: -
5. Fire Safety directives letter No: Circular of the Director of Education
6. Date of inspection: 30-9-13
7. Name of the Inspecting Officers: N.P. SHARMA
8. Name and designation of officers from the building side: Sr. Kailash Mandal Principal
9. Year of Construction: 2005
10. Applicant's letter No.: - 16-7-13

PA. 5529 sqm. C.A. 610 sqm. Nobs S-317, Nobs T-08, Nobs CR-11  
 (One Hall having 2 Nobs Exit of 1.5mts)

	Minimum Standards on fire prevention and fire safety U/R 33	DOE NBC Requirement clm 1.3.11	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	-	-	-
	• Width of internal road	-	-	-
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	2	2	MR
	• Upper Floors	R	P	MR
	• Basements	-	-	-
	b. Width of staircases	one block 1.5mts 2nd block 1.5mts	1.5mts 1.5mts	MR MR
	• Upper Floors	-	-	-
	• Basements	-	-	-
	c. Protection of exits	-	-	-
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size	1.2mts	1.2mts	MR
3	<b>Compartmentation.</b>			
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	-	-
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	-	-
	• Upper floors	12 a/c per hour	-	-

5	<b>Fire Extinguishers</b>			
	• Total numbers	2	on	MR
	• Types	ISI marked	ABC	MR
	• IS marking		yes	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	N/A	-	-
	• Length of hose reel hose	30 m	-	-
	• Nozzle diameter	5 mm	-	-
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	N/A		
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	-	-
	• Hooters' Location	-	-	-
8	<b>MOEFA</b>			
9	<b>Public Address System.</b>			
10	<b>Automatic Sprinkler System.</b>			
	• Basement	N/A		
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	-	-
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	N/A		
	• Number of hydrants per floor	-	-	-
	• Hose Box	-	-	-
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N/A		
	• Hose Box	-	-	-
13	<b>Pumping Arrangements.</b>			
	• Ground Level	N/A		
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/ Manual stopping	-	-	-
	➤ Pump House Access	-	-	-
	• Terrace level	N/A		
	➤ Discharge of pump	-	-	-
	➤ Head of the pump	-	-	-
	➤ Power Supply	-	-	-
	➤ Auto Starting of pum	-	-	-

413

14	<b>Captive Water Storage for fire fighting.</b>	N/A		
	• Underground tank capacity	—	—	—
	➤ Draw-off connection	—	—	—
	➤ Fire service inlet	—	—	—
	➤ Access to tank	—	—	—
	• Overhead Tank capacity	—	—	—
15	<b>Exit Signage.</b>			
16	<b>Provision of Lifts.</b>	N/A		
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	<b>Standby power supply</b>			
18	<b>Refuge Area.</b>			
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	<b>Fire Control Room</b>			
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	<b>Special Fire Protection Systems for Protection of special Risks, if any:</b>			

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer *(N.P. SHARMA)* **ADD R, 30-9-13**  
 Name **(N.P. SHARMA)**  
 Designation **Ass. Div. off.**

Signature of the Inspecting Officer  
 Name  
 Designation



*Donw*  
*Beish*  
*11/13*