

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001  
Fax: 23412593, Email: [cfohq.dfire@nic.in](mailto:cfohq.dfire@nic.in), Tel:- 011-23414333


NO.F6/DFS/MS/school/2013/ NDZ/1097

Dated: 17.10.2013

**FIRE SAFETY CERTIFICATE**

Certified that Govt Girls Sr. Sec. School, Chabi Ganj, Kashmiri Gate Delhi-6 comprised of ground plus three upper floors. The school premises was inspected by the officer concerned of this department on 27.09.2013 in presence of Smt Sudha Kalra, HOS of the school and found that the School management have complied with fire prevention and fire safety requirements in accordance with the Delhi Fire Service Act-2010 and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the following conditions.

Issued on 17.10.2013 at New Delhi by.

  
(Dr. G. C. Misra)  
Chief Fire Officer  
Delhi Fire Service

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-54.
2. The HOS, Govt Girls Sr. Sec School, Chabi Ganj, Kashmiri Gate Delhi-6

**Conditions for the validity of fire safety certificate**

- a. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- b. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
- c. The trained staff should be available round the clock.
- d. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
- e. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
- f. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building: Govt. Girls Sr. Sec. School, Chabi Ganj, Kashmiri Gali, Delhi-8
2. Type of Occupancy : Educational (G + 3)
3. Type of Case : New Case / ~~Renewal~~
4. Details of previous NOC : N/A
5. Fire Safety directives letter No : DOE F.16/Estab/CC/Fire Safety/2011/3398 to 3399 Dt. 01/02/2011
6. Date of inspection : 27-09-2013
7. Name of the Inspecting Officers : Sanjay Kumar Tomar, DO
8. Name and designation of officers  
from the building side : Mrs Sudha Kalra, HOS
9. Year of Construction : 1956
10. Applicant's letter No. : 335 Dated 18/7/2013

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible to fire engine	4.5 mtr Provided	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-	-	-
	• Upper Floors	One	Two Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-	-	-
	• Upper Floors	1.5 mtr	2.081-4 mtr P.	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-	-	-
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	One	Provided	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	N/A	N/A	N/A
3	<b>Compartmentation.</b>			
	• Fire check door			
	• Sealing of electrical shafts			
	• Fire Rating of shaft door		N	
	• Water Curtain		A	
	• Fire Dampers			
4	<b>Smoke Management System.</b>			

5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	16	23 Provided	MR
		ISI marked	Provided	MR
		Required	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	One on each floor	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>		N	A
8	<b>MOEFA</b>			
9	<b>Public Address System.</b>			
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>		N	A
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>		N	A
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>		N	A
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> </ul> </li> </ul>		N	A
		450 LPM	Provided	MR

S/H

14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>Overhead Tank capacity</li> </ul>		N	
			A	
		10,000 lbs	12,000 lbs Provided	MR
15	<b>Exit Signage.</b>			
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>		N	
			A	
17	<b>Standby power supply</b>			
18	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>		N	
			A	
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>Detector System Panel</li> <li>Flow Switch Panel</li> <li>PA System Panel</li> <li>Batter backup</li> <li>Building Floor Plans</li> </ul>		N	
			A	
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation

*[Signature]*

Sanjay Kumar Tomar

Divisional Officer

DO (CD)

Submitted please -  
15/10/13

