

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
Fax: 23412593, Email: cfohqdlfire@nic.in, Tel:- 011-23414333


No. F.6/DFS/MS/EH/2013/SZ/ 1126

Dated: 23 / 10 / 13

FIRE SAFETY CERTIFICATE

Certified that the Nanking Chinese Restaurant at C-6, Plot No. 6, Opp. D.P.S. School, Vasant Kunj, New Delhi running at ground plus two upper floors of the building comprised of ground plus two upper floors was granted NOC by this department vide letter No. F6/DFS/MS/EH/2010/1592 dated 31.05.2010. The premises was re-inspected by the officer concerned of this department on 04.10.2013 in the presence of Mr. Roshan (Manager) of the restaurant and observed that fire safety norms as required under Rule 33 of Delhi Fire Service Rules, 2010 have deemed complied and that the building / premises is fit for occupancy class-D "Assembly building Restaurant" with effect from 23 / 10 / 13 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on 23 / 10 / 13..... at New Delhi by


(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The DHO(South Zone), Office of Deputy Health Officer, M.C.D. Health Department South Zone, Green Park, New Delhi,
2. The Manager, Nanking Chinese Restaurant at C-6, Plot No. 6, Opp. D.P.S. School, Vasant Kunj, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The Basement shall be used strictly as per the provisions of Building Bye Laws.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service 'Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1	Name & address of the building	M/s Nanking Chinese Restaurant, C-6, Plot No. 6, Opp. Delhi Public School, Vasant Kunj, New Delhi		
2	Type of Occupancy	Assambly "D"		
3	Type of case	Renewal		
4	Details of previous NOC	F6/MS/DFS/EH/2010/1592 Dated 31.05.2010		
5	Fire safety directives letter No	Nil		
6	Date of inspection	4.10.2013		
7	Name of the inspecting Officers :	D.O. (South) D.P. Bhardwaj,		
8	Name and designation of officers	Sh. Roshan (Manager)		
	from the building side			
9	Year of construction		(Ground, plus two and upper floors)	
10	Applicant's letter No.	Nil	15.09.2013	(Restaurant running at ground plus two upper floors)
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 mtrs.	Provided	MR
	2) Gate width	N/A	N/A	MR
	3) Width of internal road	N/A	N/A	MR
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	Old Case	2 Nos Provided	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	Old Case	110 cm & 60 cm Provide	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Old Case	One	MR
	e. Width of corridor	N/A	N/A	MR
	f. Door size	Old Case	2 Nos. (1.75 & 0.76 Mtr) Provided	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Exhust Fans Provided.	MR
5	Fire Extinguishers			
	total numbers		8 Nos	MR
	Types		ABC, Water Co2	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	1 Nos.	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	Required	Provided	MR
	sprinkler above false ceiling	N/A	N/A	MR
11	Internal Hydrants			
	Size of riser/down-corner	100 MM	Provided	MR
	Number of Hydrants per floor	One	Provided	MR
	hose Box	One	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	MR
	hose box	N/A	N/A	MR
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	MR
	b. Head of main pump	N/A	N/A	MR
	c. Number of main pumps	N/A	N/A	MR
	d. jockey pump out put	N/A	N/A	MR
	e. jockey pump head	N/A	N/A	MR
	f. Standby Pump output	N/A	N/A	MR
	g. Stanby Pump head	N/A	N/A	MR
	h. Auto Starting/Manual stopping	N/A	N/A	MR
	pump house access	N/A	N/A	MR
	2. Terrace level			
	a. Discharge of pump	Old Case	450 & 180 LPM Provided	MR
	b. head of the pump	35 mtr	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	Provided	MR
	a. Draw-off connection	N/A	Provided	MR
	b. fire service inlet	N/A	Provided	MR
	c. Access to tank	N/A	Provided	MR
	Over head tank Capacity	Old Case	5,000 ltr Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	MR

17	Standby power supply	Required	Provided	MR
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	MR
	b. Flow switch Panel	N/A	N/A	MR
	c. PA system Panel	N/A	N/A	MR
	d. Batter backup	N/A	N/A	MR
	e. Building floor plans	N/A	N/A	MR
20	Special Fire Protection systems for protection of special risks, if any:			

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule. The grant of Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/

Accordingly DFA is put up for your approval and signature please.

Signature of the inspecting officer

Name D. P. Bhardwaj

Designation : Divisional Officer (South)

