

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

Fax : 23412593, E-mail: cfohq.dlfire@nic.in Tel :- 011-23414333

No: F6/DFS/MS/2013/NDZ/1112

Dated: 22/10/13

FIRE SAFETY CERTIFICATE

Certified that the **All India Women's Conference, Sarojini House** located at 6, Bhagwan Das Road, New Delhi comprised of basement, ground + 6 upper floors, was granted NOC by this department vide letter No. F6/DFS/MS/08/2244 dated 06-08-08. The premises was re-inspected by the officer concerned of this department on 02-09-2013 in the presence of Mr. Kuldeep Panday and found that the said hostel building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of hostel with effect from 22/10/13 2013 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 22/10/13 at New Delhi by.



(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

All India Women's Conference, Sarojini House, 6, Bagwan, Dass Road, New Delhi

INSPECTION REPORT

1. Name & address of the building : **All India Women's Conference, Sarojini House, 6, Bagwan Dass Road, New Delhi**
2. Type of Occupancy : Residential
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/08/2224 dated 06-08-08
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 02-09-2013
7. Name of the Inspecting Officer : Sh. D.S. Yadav (D.O.)
8. Name and designation of Officer from the building side : Mr. Kuldeep Panday
9. Year of Construction : 1977 Starting Year
10. Applicant's letter No. : 141/PB/2013 dated 24-06-2013

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR (Old Case)
1.	Access of building			
	• Road width	6 mtrs.	More then 12 mtrs.	MR
	• Gate width	6 mtrs.	More then 6 mtrs.	MR
	• Width of internal road	6 mtrs.	More then 6 mtrs.	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	04	04	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper floors	100 cms	two staircase 125cms each and two staircase 90cms each	MR
	• Basements	100 cms.	Two staircase 170 cms each	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	03	03	MR
	e. Width Of Corridor	190 cms & 140cms	Provided	MR
	f. Door Size	N/A	N/A	N/A
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	One hour	Provided	MR
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	30 a/c per hour	Exhaust fans	MR

All India Women's Conference, Sarojini House, 6, Bagwan, Dass Road, New Delhi

	• Upper floors	12 a/c per hour	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	36	104	MR
	• Types	Water Co2 & A.B.C. type.	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	3,2 & 1	Provided	MR
	• Length of hose reel hose	30 M	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system:- smoke detector provided in AIWC office, Agakha Hall and bank			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Ground floor	Provided	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	UPS	Provided	MR
	• Hooters' Location	Near gate	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System/Intercom	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	1 st & 2 nd (three), 3 rd to 5 th (two), 6 th (one)	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	06	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	2280 LPM	Provided	MR
	➤ Head of main pump	70 mtrs	Provided	MR
	➤ Number of main pumps	one	Provided	MR
	➤ Jockey pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	70 mtrs	Provided	MR
	➤ Standby Pump out put/Diesel Driven	2280 LPM	Provided	MR
	➤ Standby Pump Head	70 mtrs	Provided	MR
	➤ auto Staring/Manual stopping	Yes	Provided	MR
	➤ Pump House Access	Yes	Provided	MR
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	100000	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR

All India Women's Conference, Sarojini House, 6, Bagwan, Dass Road, New Delhi

	• Overhead Tank capacity	20000 ltrs.	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts (Two lift provided)			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	Required	Provided at G.F.	MR
	➤ Flow Switch Panel	Required	Provided at G.F.	MR
	➤ PA System Panel	Required	Provided at G.F.	MR
	➤ Batter backup	Required	Provided	MR
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	01 Co2 & 01 ABC fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer

Name
Designation

Signature of the Inspecting Officer

Name *Dhawan*
Designation *Divisional Officer (C.D.)*