

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No.F.6/DFS/MS/School/2013/ 52/1117

Dated: 22/10/13

FIRE SAFETY CERTIFICATE

Certified that the building of **Shri F M S Public School** located at Jai Vihar, Phase-II, Najafgarh, New Delhi-110043 comprised of ground floor only owned/occupied by the school management was inspected by the officer concerned of this department on 04.10.2013 in the presence of Smt. Neelam (Manager) and found that the school management have complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on.....22/10/2013.....at New Delhi.


(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Chairman,
Shri F M S Public School,
Jai Vihar, Ph-II, Najafgarh, N.D-43.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

ole
OH

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

N/I

Ground floor only

INSPECTION REPORT

1. Name & address of the building: Shri FMS Public School, Jai Vihar Ph-II, Najafgarh, New Delhi-110043
2. Type of Occupancy : _____
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. _____ Dated _____
5. Fire Safety directives letter No : _____
6. Date of inspection : 04.10.2013
7. Name of Inspecting Officer : ADO Sandeep Duggal
8. Name and designation of officers
From the building side : Smt Neelam (Manager)
9. Year of Construction : 2004-2005
10. Applicant's letter No. : Nil dated 10/09/2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<u>Accessible</u> — —	<u>05 mtr</u> <u>05 mtr</u>	<u>MR</u> <u>MR</u>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	—	—	<u>Ground floor only</u>
	• Basements	—	—	<u>No Basement</u>
	b. Width of staircases			
	• Upper Floor	—	—	<u>Ground floor only</u>
	• Basements	—	—	<u>No Basement</u>
	c. Protection of exits			
	• Fire check door	—	—	—
	• pressurization	—	—	—
	d. No. of continuous staircases to terrace	—	—	<u>GF only</u>
	e. Width of Corridor	—	—	—
	f. Door Size	<u>1m</u>	<u>1m</u>	<u>MR</u>
3.	Compartmentation			
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4.	Smoke Management System			
	• Basements	<u>30 a/c per hour</u>	—	<u>No Basement</u>
	• Upper floors	—	<u>Natural ventilation</u>	<u>MR</u>

Sam

N/2

		12 a/c per hour		
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	D4 No ¹³ ABC/CO ₂ ISI marked	Provided do ISI marked	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	_____ 30 m 5 mm	_____ _____ _____	_____ _____ _____
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	_____ _____ _____ _____ _____	_____ _____ _____ _____ _____	_____ _____ _____ _____ _____
8.	MOEFA			
9.	Public Address System			
		_____	Provided	_____
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	_____ _____ _____	_____ _____ _____	_____ _____ _____
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	_____ _____ _____	_____ _____ _____	_____ _____ _____
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	_____ _____	_____ _____	_____ _____
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping 	_____ _____ _____ _____ _____ _____ _____ _____	_____ _____ _____ _____ _____ _____ _____	_____ _____ _____ _____ _____ _____ _____

Sam

N/3

Shri FMS Public School, Jai Vihar Phase-II, Najafgarh,
NDelhi-43

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	—	—
15.	Exit Signage.			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	No lift
		—	—	—
		—	—	—
		—	—	—
		—	—	—
17.	Standby power supply	—	—	—
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
		—	—	—
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
20.	Special Fire Protection System for Protection of special Risks, if any:	—	—	—

San

N/4

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note :- School building is comprised of ground floor only. There are less than 45 no.s of students in each class as per letter no. nil dated 04/10/2013 given by manager of school. FSC is recommended please.

Sandeep
14/10/13

Signature of Inspecting Officer

Name Sandeep Duggal

Designation Asst. Divisional officer

~~Signature of Inspecting Officer~~

~~Name~~

~~Designation~~

