

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No: F.6/DFS/MS/School/2013/ 82/1119

Dated: 22/10/13

FIRE SAFETY CERTIFICATE

Certified that the building of **Govt. Co-Ed. Sr. Sec. School**, Mundhela Kalan, New Delhi -110073 comprised of ground floor plus two upper floors but the school is running at ground floor and first floor only, having total 36 rooms (Including Class Rooms, Office, Library, Comp. Room, Agriculture Lab & Store etc) owned/occupied by The Govt. of NCT of Delhi was inspected by the officer concerned of this department on 04.10.2013 in the presence of Sh. Kedar Lal Meena (Vice Principal) and found that the Govt. of NCT of Delhi have complied with the fire prevention and fire safety requirements in accordance with the Circular No- F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and that the building is fit for occupancy class "Educational" for Ground plus 1st floor only, with effect from the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on 22/10/2013.....at New Delhi



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to: -

1. The Vice Principal,
Govt. Co-Ed. Sr. Sec. School,
Mundhela Kalan, New Delhi-110073.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

etc
Copy

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

N/3

Ground floor plus two upper floors but
School running on ground & first floor**INSPECTION REPORT**

1. Name & address of the building: Govt. Co-ed Sr Sec. School, Mundhela kalan, N Delhi - 73
2. Type of Occupancy : Educational
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. _____ Dated _____
5. Fire Safety directives letter No : _____
6. Date of inspection : 04.10.2013
7. Name of Inspecting Officer : ADO Sandeep Duggal
8. Name and designation of officers
From the building side : Mr Kedar Lal Meena (vice-principal)
9. Year of Construction : 1972
10. Applicant's letter No. : Nil dated 10.07.2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible — —	10 mtr 385, 296, 90 cms —	MR MR —
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 —	02 —	MR No Basement
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	— —	140 & 185 cms —	MR No Basement
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door pressurization 	— —	— —	— —
	d. No. of continuous staircases to terrace	—	one	—
	e. Width of Corridor	—	180 cms	—
	f. Door Size	—	90/95/100 cms one door only	MR (old building)
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	— — — — —	— — — — —	— — — — —
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour — —	— — Natural Ventilation	No Basement MR

San

N/4

M

		12 a/c per hour	—	—
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	<p>14 Nos ABC 4 CO₂ ISI marked</p>	<p>provided — do — ISI marked</p>	<p>MR MR MR</p>
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	<p>— 30 m 5 mm</p>	<p>— — —</p>	<p>— — —</p>
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	<p>— — — — —</p>	<p>— — — — —</p>	<p>— — — — —</p>
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	<p>— — —</p>	<p>— — —</p>	<p>— — —</p>
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	<p>— — —</p>	<p>— — —</p>	<p>— — —</p>
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	<p>— —</p>	<p>— —</p>	<p>— —</p>
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping 	<p>— — — — — — — —</p>	<p>— — — — — — — —</p>	<p>— — — — — — — —</p>

P
1

Sam

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	—	—
15.	Exit Signage.			
16.	Provision of Lifts:			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	No lift
		—	—	do
		—	—	do
		—	—	do
		—	—	do
17.	Standby power supply	—	—	—
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
		—	—	—
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
20.	Special Fire Protection System for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note :- School building is comprised of ground floor, first floor and second floor but school is running on ground and first floor only as per the letter given by the Vice principal (ref. no FI/GCE/MK/ dated 03/08/2013). It is also declared in this letter that school building was constructed in 1972 and number of students are less than 45 in each class room. FSC is recommended please.

Sandeep
14/11/13
Signature of Inspecting Officer

Name Sandeep Duggal
Designation Assst. Divisional officer.

Signature of Inspecting Officer

Name
Designation