

No F 6 / DFS / MS / Hotel / 2013 / ND2/1145

Dated 30/10/13

FIRE SAFETY CERTIFICATE

Certified that the **Mahesh Guest House at, T-316, Ram Dwara Road, near Khanna Cinema, Pahar Ganj, New Delhi – 110055** comprised of ground floor (reception + office), 1st floor to 4th floor (04 guest rooms at each floor) total 16 guest rooms was granted NOC by this department vide letter No. F6/DFS/HQ/GH/2010/2720 dated 17-09-2010. The premises was re-inspected by the officer concerned of this department on 03-08-2013 in the presence of Mr. Deepak Gola (Owner-Son) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of 16 guest rooms with effect from -----
30/10/2013 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...30/10/13..... at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414333

Copy to:-

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi – 110049 w.r.t. letter No 33635/Addl. C.P./Lic(H) New Delhi 05-07-2013.
2. Mahesh Guest House at,
T-316, Ramdwara Road, Near Khanna Cinema, Pahar Ganj, New Delhi – 110055

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

no/5

INSPECTION REPORT

1. Name & address of the building : MAHESH GUEST HOUSE T-316, RAM DWARA ROAD, KHANNA
near
 : CINEMA, PAHAR GANJ NEW DELHI.

2. Type of Occupancy : Residential (guest House) G+4 Floors

3. Type of Case : RENEWAL

4. Details of previous NOC : F6/DFS/HQ/GH/2010/2720 Dt 17/09/2010

Fire Safety directives Letter No. : NA

Date of inspection : 03/08/2013

Name of the Inspecting Officer : M.K.Sharma (Assistant Divisional Officer)

Name and designation of Officer
 from the building side : Sh.Deepak Gola (Owner-Son)

Year of Construction : 1999

10. Applicant's letter No. : 33635/Addl.CP/Lic(H) dt New Delhi 05/07/2013

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site (PSS Area)	Remarks MR/NMR (P.S.S Area)
1.	Access of building			
	• Road width	NA	3 mt	MR
	• Gate width	1.5 Mt	1.5 Mt	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a.Number of staircases	01	P	MR
	• Upper floors	01	P	MR
	• Basements	NA	NA	NA
	b.Width of staircases			
	• Upper floors	800 MM	1250 MM	MR
	• Basements	NA	NA	NA
	c.Protection of exits			
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA

MESH

	c.No of continuous staircase to terrace	01	P	MR
	d.Width Of Corridor	1250	2Mt	MR
	e.Door Size	-NA-	-	-
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	• Total numbers	06	08	MR
	• Types	ABC,Co ₂ , Wco ₂	P	MR
	• IS marking	YES	P	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	01	P	MR
	• Length of hose reel hose	30	P	MR
	• Nozzle diameter	05	P	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	YES	P	MR
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA

N/7

11	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements			
	○ Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	• Head of main pump	NA	NA	NA
	• Number of main pumps	NA	NA	NA
	• Jockey pump out put	NA	NA	NA
	• Jockey pump head	NA	NA	NA
	• Standby Pump out put	NA	NA	NA
	• Standby Pump Head	NA	NA	NA
	• auto Staring/Manual stopping	NA	NA	NA
	• Pump House Access	NA	NA	NA
	○ Terrace level	NA	NA	NA
	• Discharge of pump	NA	NA	NA
	• Head of the pump	450 LPM	450 LPM	MR
	• Power supply	30 Mt	P	MR
	• Auto starting of pump	YES	P	MR
		-	-	-
14	Captive water Storage for fire fighting			
		NA	NA	NA
	• Under ground tank capacity	NA	NA	NA
	• Draw of connection	NA	NA	NA
	• Fire service inlet	NA	NA	NA
	• Access to tank	YES	P	NA
	• Overhead Tank capacity	2500	P	MR
15	Exit Signage			
		YES	P	MR
16	Provision of Lifts			
		NA	NA	NA

mesh

N/8

	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of lift lobby • Communication in lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	NR	P	MR
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	YES	ABC	MR

The fire protection systems provided in the building were tested, checked and found non-functional at the time of inspection.

Keeping in view the compliance of the minimum standards on Fire prevention and fire Safety required under the rules 35 of the Delhi fire service Rules 2010/ FSC is recommended.



Do (ED)

submitted please
28-10-13

M.K. Sharma
22/10/13
Signature of the Inspecting Officer

Name :- M.K. Sharma
Designation :- A. D.O. (CC)