

NO. F6/DFS/MS/School/2013/ SZ/ 1148

DATED: 30/10/13

FIRE SAFETY CERTIFICATE

Certified that the Solanki Public School, Nasirpur Dabri Road, Durga Park, New Delhi-110045 comprised of ground plus one upper floor was granted NOC by this department vide letter no. F6/MS/DFS/2010/2884 dated 05.10.2010. The premises was re-inspected by the officers concerned of this department on 23.10.2013 in the presence of Smt Indera Davi (Manager) and observed that fire safety measures are in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi have deemed complied and that the building / premises is fit for occupancy class B "Educational building" with effect from 30/10/13 for a period of **three years**, subject to condition as mentioned below.

Issued on 30/10/13 at New Delhi by


(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

Copy to,

1. The Director (Edu.), SDMC, 23rd floor, Civic Centre, Minto Road, New Delhi
2. Smt. Indera Davi (Manager), Solanki Public School, Nasirpur Dabri Road, Durga Park, New Delhi-110045.

Conditions for the validity of fire safety certificate

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Solanki Public School, Nasirpur Dabri Road, Durga Park, New Delhi-110045	
2	Type of Occupancy	Educational Building "B"	
3	Type of case	Renewal	
4	Details of previous NOC	F6/MS/DFS/2010/2884 dated 05.10.2010	
5	Fire safety directives letter No	Edu. Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.	
6	Date of inspection	23.10.2013	
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj	
8	Name and designation of officers from the building side	Smt. Indera Davi (Manager)	
9	Year of construction	1995	
10	Applicant's letter No.	10/13 Dated 07.10.2013	(Ground plus one upper floor)

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
--------	---	-----------------	------------------	------------------

1	Access to building			
	1) Road width	Required	9 Mtr Provided	MR
	2) Gate width	Old Case	Provided	MR
	3) Width of internal road	N/A	N/A	N/A

2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	Old Case	2 Nos. Provided	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtr	1.5 Mtrs each Provided	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	One Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	Old Case	1 Mtr Provided	MR

3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Natural Vent.	MR

5	Fire Extinguishers			
	total numbers		8 Nos	MR
	Types		Co2 & ABC	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	N/A	Provided	MR
	Length of Hose reel hose	N/A	30 Mtr Provided	MR
	Nozzle Diameter	N/A	5mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	220 LPM Provided	MR
	b. head of the pump	N/A	35 Mtr Provided	MR
	c. Power supply	N/A	Provided	MR
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	2500 Ltrs Provided	MR
15	Exit Signage.	N/A	N/A	N/A
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

2

N/S

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	Total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	N/A		

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/ Accordingly DFA is put up for your approval and signature please.

~~DO.SW~~

S.P. Bhardwaj
24/1/13

Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)