

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No: F6/DF3(M5)SH/2013/W21 1143

Dated: 30/10/13

**FIRE SAFETY CERTIFICATE**

Certified that the **Buzz (Next Level Food and Beverages Pvt. Ltd.)**, located at 2<sup>nd</sup> floor of 1/83, Club Road, Punjabi Bagh, New Delhi - 110026 in a building comprised of basement, ground plus two upper floors with 2 rooms at terrace, owned and occupied by **Buzz (Next Level Food and Beverages Pvt. Ltd.)** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on **26-09-2013** in the presence of **Sh. Karan Chawla** and that the building / premises is fit for the occupancy class "**Assembly**" **Group D Sub Division D - 5** with effect from 30.10.13.... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30.10.13..... at New Delhi.

  
(Santokh Singh)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250

Copy to:-

1. Dy. Health Officer (West Zone),  
South Delhi Municipal Corporation,  
Rajouri Garden, New Delhi - 110027.
2. Sh. Kapil Negi,  
1/83, 2<sup>nd</sup> Floor Club Road,  
Punjabi Bagh, New Delhi - 110026.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. Basement shall be used as per building bye laws.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/L

**INSPECTION REPORT**

1. Name & address of the building: Buzz Next Level Food & Beverages Pvt. Ltd.,  
1183, 2nd floor, Club Road, West Punjabi Bgh,  
New Delhi
2. Type of Occupancy : Assembly
3. Type of Case : NEW
4. Details of previous NOC : Letter No —
5. Fire Safety directives Letter No. : —
6. Date of inspection : 26/9/13
7. Name of the Inspecting Officer : Mukesh Verma ADD(MM)
8. Name and designation of Officer : Karan chowla  
from the building side :
9. Year of Construction : 2000
10. Applicant's letter No. : D/3187HD/W2/2013 dated 18/7/13

Area = 3400 sq.ft. (approx)

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL / NBC-IV Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9m	15m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	2	1 staircase + 1 Ramp	MR
	b. Width of staircases			
	• Upper floors	2 x 1.5m	158cm 150cm	MR
	• Basements	2 x 1.5m	158cm Ramp 2.5m	MR
	c. Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	2	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2m x 2	Provided	MR



N/2

M

3.	Compartmentation			
	• Fire check door	Reqd. in basement	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour Exhaust fan	Provided	MR
	• Upper floors	12 a/c per hour Exhaust fan	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	6	Provided	MR
	• Types	ABC & CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Yes	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Inside	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NR	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR

11.	Internal Hydrants			
	• Size of riser/down- comer	100mm	Provided	MR
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants		N/A	
	• Hose Box			
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump			
	➤ Head of main pump			
	➤ Number of main pumps			
	➤ Jockey pump out put			
	➤ Jockey pump head			
	➤ Standby Pump out put			
	➤ Standby Pump Head			
	➤ Auto Staring/Manual stopping			
	➤ Pump House Access			
	• Terrace level			
	➤ Discharge of pump	2 x 450 lpm	Provided	MR
	➤ Head of the pump	60m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	15000 lts.	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			



N/4

	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area			
	➤ Location		N/A	
19.	Fire control room			
	➤ Detector system panel			
	➤ Flow Switch Panel			
	➤ PA System Panel			
	➤ Batter backup		N/A	
	➤ Building Floor Plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any;		N/A	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/~~issue shortcomings as noted at serial numbers~~ .....

Signature of the Inspecting Officer *[Signature]* 8/4/13

Name *Mukesh Verma*

Designation *ADD(MN)*

Signature of the Inspecting Officer *[Signature]*

Name

Designation

