

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F61DPS7MS7EH/2013/52/1169

Dated: 4 / 11 / 2013

FIRE SAFETY CERTIFICATE

Certified that Amitabh Guest House, located at E-23, Bunglow Road, Kamla Nagar, Delhi-110007 was granted NOC by this department vide letter no F-6 / DFS / MS / GH / 2010 / 3205 Dated 19/11/2010. The premises was re-inspected by the officers concerned of this department on 29 / 10 / 2013 in the presence of Mr. Mehra (Manager) and found that the building have deem complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit for Restaurant & Assembly occupancy with effect from 4 / 11 / 2013 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of Delhi Fire Service Rules, 2010.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the restaurant are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 4 / 11 / 2013 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dfire@nic.in

- Copy to: 1. The Joint Commissioner of Police Licensing Unit 1st Floor P S Defence Colony New Delhi. In reference letter no. 48030/Joint C. P./Lic.(H) dated 17/09/2013.
2. Sh. Om Prakash Bhola (Prop.) Amitabh Guest House, E-23, Bunglow Road, Kamla Nagar, Delhi-110007

Guest House on F-Floor
 Restaurant on G-Floor
 Residence on Third Floor
 Basement for Storage

INSPECTION REPORT

1. Name & address of the building: Amitabh Guest House, E-23 Bungalow Rd, Kaula Nagar, Delhi
2. Type of Occupancy: Guest House & Restaurant (Residence & Assembly)
3. Type of Case: New Case / Renewal
4. Details of previous NOC: F-6/DRS/MS/S.H/2010/3205 dt-19-11-10
5. Fire Safety directives letter No: -
6. Date of inspection: 29-10-13
7. Name of the Inspecting Officers: V. P. N. Kental
8. Name and designation of officers from the building side: Mr. Mehra (Manager)
9. Year of Construction: 5
10. Applicant's letter No: 483/ Joint C P/ Lic (H) dt-17-9-13.

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	R	P	M/R
	• Gate width	R (4.5 mtr)	P	M/R
	• Width of internal road	N.A	N.A	N.A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	One	P	M/R
	• Basements	One	Two	M/R
	b. Width of staircases			
	• Upper Floors	old case	old case	M/R
	• Basements	old case	old case	M/R
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace			
	g. Width of Corridor	N/A	N/A	N.A
	h. Door Size	old case	old case	old case
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	—	—
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour	N/A	✓
			✓	
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	2 W Co2 & ABC Type/Co2 Type ISI marked on each floor	2 on each floor W Co2, DCP Type and Co2 Type	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	1 30 m 5 mm	P P P	M/R M/R M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 		N.A	✓
8	MOEFA	R	P	M/R
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	R N/A N/A	P N/A N/A	M/R N/A N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	Downcomer one one	P P P	M/R M/R M/R
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 		N/A	✓

13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pum 			
			N/A	
		450 LPM	P	M/R
		180 LPM	P	M/R
		R 40 MPA	P	M/R
		R	P	M/R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 			
			N/A	
		20000 Ltr.	P	M/R
15	Exit Signage.	R	P	M/R
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 			
			N/A	
17	Standby power supply	R	P	M/R
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
			NA	
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel 	R	P	M/R

	<ul style="list-style-type: none"> • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:		N.A	
			No spl- size seen at the time of inspection.	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

beant
Signature of the Inspecting Officer

Name

Designation

