


No.F6/DFS/MS/2013/52/1166

Dated: 01/11/13

FIRE SAFETY CERTIFICATE

Certified that the **Anand Niketan Club and Multipurpose Hall** located at **Anand Niketan, New Delhi-110021**. comprised of **Basement ,Ground + 1 Upper Floor** was granted NOC by this department vide letter No.F6/DFS/MS/10/975 dated 31/03/10. The premises was re-inspected by the officer concerned of this department on 19/10/13 in the presence of **Mr. Satender Kumar Sharma** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group D Assembly Building** with effect from 01/11/13 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 01/11/13 at New Delhi by.


(Dr.G.C.Misra)
Chief Fire Officer
Delhi Fire Service

Copy to:- (1) D.E.O. RESTT.,
Govt. of NCT of Delhi, Office of The Commissioner of Excise
Entt. & Tax Deptt. L & J Block, I.P. Estate, Vikas Bhawan, New Delhi-
110002.

(2) Anand Niketan Club and Multipurpose Hall,
Anand Niketan, New Delhi-110021.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. In case the temporary structure is erected the party should apply separately to this department.

H/12

old case

INSPECTION REPORT

1. Name & address of the building:- Anand Niketan Club and Multipurpose Hall located at Anand Niketan, New Delhi-110021.
2. Type of occupancy:- Group D Assembly Building.
3. Type of case:- Renewal
4. Details of previous NOC:- No.F6/DFS/MS/10/975 dated 31/03/10.
5. Fire safety directives No.- F6/DFS/MS/BP/2001/272 dated 14/02/01.
6. Date of inspection:- 19/10/13
7. Name of the inspecting officer:- A.D.O. S.S. Kaushik
8. Name & designation of officer
From the building side:- Mr. Satender Kumar Sharma.
9. Year of construction:- 2004.
10. Applicant's letter No:- ANC/164 dated 27/09/13 ,Basement ,Ground + 1 Upper Floor.

Old case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	12 Mtrs	Provided.	MR
	2) Gate width	05 Mtrs	Provided.	MR
	3) Width of internal road	NA	NA.	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	3 Nos.	3 Nos.	MR
	2. Basements	2 Nos.	2 Nos.	MR
	B. Width of staircase			
	1. Upper floors	Required 1.50 mtr.	1.50 mtr., 1.20 mtr. & 1.25 mtr.	MR old case
	2. Basements	Required 1.50 mtr.	1.50 mtr. & 1.20 mtr.	MR old case
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	One	One	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtrs	1 mtrs	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Exhaust Fan	MR

S. Kaushik

	2) Upper floors	12 a/c per hour	Exhaust Fan	MR
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	40 Nos.	MR
	2) Types		ABC, Co2 & W.Co2	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	2 Nos.	Provided	MR
	2) Length of hose reel hose	30 mtrs	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Smoke & Heat	Smoke	MR
	2) Location of main panel	Ground floor	Yes	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	Required	Available	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	Required	100 mm.	MR
	2) Number of hydrants per floor	2 Nos.	2 Nos.	MR
	3) Hose box	2 Nos.	2 Nos.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	3 Nos.	Provided.	MR
	2) Hose box	3 Nos.	Provided.	MR

13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	1620 LPM	1620 LPM	MR
	b) Head of main pump	56 mtr.	56 mtr.	MR
	c) Number of main pump	1 Nos.	1 Nos.	MR
	d) Jockey pump out put	180 LPM	180 LPM	MR
	e) Jockey pump head	56 mtr.	56 mtr.	MR
	f) Stand by pump output	1620 LPM	1620 LPM	MR
	g) Stand by pump head	56 mtr.	56 mtr.	MR
	h) Auto starting/Manual stopping	Yes	Yes	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	50,000 ltrs.	50,000 ltrs. (swimming pool)	MR
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	Yes	Provided	MR

Mausy

	c) Access to tank	Yes	Provided	MR
	d) Over head tank capacity	20,000 ltrs.	20,000 ltrs	MR
15.	Exit Signage.	Yes	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	Yes	Provided	MR

019
cool

	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Yes	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/-----

Accordingly DFA is put up please.

Signature of the inspecting officer

Signature of the inspecting officer

Name :-

Name:- S.S. Kaushik

Designation:-

Designation:-Asstt. Divisional Officer

Do Saith

W. K. ... 22/11/13

S.S. Kaushik
22/11/13