

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/school/2013/W2/1164 Dated: 01/11/2013

**FIRE SAFETY CERTIFICATE**

Certified that the Nav Nitin Public School, Gali no. 12, Libas pur, Delhi-110042 comprised of Ground + two upper floor owned/occupied by Nav Nitin Public School has already been issued fire safety certificate vide letter no. F-6/DFS/MS/2007 /135 dated 16/01/2007 . The premises was re-inspected by the officer from this department on dated 04/10/2013 in the presence of Mrs. Raj Kumari and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have there fore deemed complied with the requirements of circular issued by Director of Education letter dated 17/01/2005 and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 01 / 11 /2013 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 01 / 11 / 13 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
[cfowz.dfire@nic.in](mailto:cfowz.dfire@nic.in)

**Copy to:**

1. The Principal, Nav Nitin Public School, Gali no. 12, Libas pur, Delhi-110042
2. The Director of Education, Old Secretariat, Delhi



(9+2)

**INSPECTION REPORT**

1. Name & address of the building: Nav Nitin Public School, Gali No-12, Libas pur, Delhi-42
  2. Type of Occupancy : **Educational**
  3. Type of Case : Renewal
  4. Details of previous NOC : F-6/MS/DFS/2007/135 dated 16/01/2007
  5. Fire Safety directives letter No : Circular of the Director of Education
  6. Date of inspection : 04/10/2013
  7. Name of the Inspecting Officers : N.P Sharma ADO (Rohini)
  8. Name and designation of officers  
from the building side : Mr. Raj Kumar (H.M)
  9. Year of Construction : 1993
  10. Applicant's letter No. : Nil dated 03/09/2013
- PA 354 sqmtr CA 354 sqmtr, No's - 200, No's T - 5, No's CR -7

	Minimum Standards on fire prevention and fire safety U/R 33	DOE NBC Requirement CU DF 17-1-05	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible	M/R
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	02	02	M/R
	• Upper Floors	02	02	M/R
	• Basements	—	—	—
	b. Width of staircases	Old Case	Old Case	Old Case
	• Upper Floors	Old Case	Old Case	Old Case
	• Basements	—	—	—
	c. Protection of exits			
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	—	—	—
3	<b>Compartmentation.</b>			
	• Fire check door	—	—	—




	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	N.A N.A	N.A N.A
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers (One @ 300 sqmtr)</li> <li>Types</li> <li>IS marking</li> </ul>	03 ISI marked	09 ABC type Yes	M/R M/R M/R
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	One 30 m 5 mm	P P P	M/R M/R M/R
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N.A N.A N.A N.A N.A	N.A N.A N.A N.A N.A	N.A N.A N.A N.A N.A
8	<b>MOEFA</b>			
		—	—	—
9	<b>Public Address System.</b>			
		—	—	—
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	— — —	— — —	— — —
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	N/R N/R N/R	P One One	N.A N.A N.A
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	— —	— —	— —
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>	N.A N.A	N.A N.A	N.A N.A

	<ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>	N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		R	P	M/R
		450 LPM	P	M.R
		40 M	P	M.R
		—	—	—
		—	—	—
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	—	—	—
		—	—	—
		—	—	—
		—	—	—
		5000 ltr	9000 ltr	M.R
15	<b>Exit Signage.</b>			
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
17	<b>Standby power supply</b>	—	—	—
18	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	—	—	—
		—	—	—
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A

20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—
----	--	---	---	---

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....



Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name N. P. SHARMA

Name

Designation A. D. O

Designation