

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID: cfohq.dfire@nic.in

No F 6 / DFS / MS / GH / 2013 / *N02/1173*

Dated *08/11/13*

FIRE SAFETY CERTIFICATE

Certified that the **Bercos Lounge (A unit of Dhaba Express)** located at, Shop No G-2/43 middle circus, **Connaught Palace, New Delhi** comprised of basement, ground plus two upper floor and Restaurant running at ground floor & basement is use as storage , was granted NOC by this department vide letter No. F6/DFS/MS//2008/EH/141 dated 18-01-2008. The premises was inspected by the officer concerned of this department on 24-10-2013 in the presence of Mr. Rawat (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy with effect from ~~---08/11/2013~~ *08/11/2013* for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... *08/11/13* at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414333

Copy to:-

1. The Joint Secretary (Tourism), Tourism Department, GNCT of Delhi Room No 176-183 old Secretariat, Delhi - 110054 w.r.t. letter No F.22/11/Tsm/04/339/4-11 dated 06/01/2009
2. The Bercos Lounge (A unit of Dhaba Express)
Shop No G-2/43 middle circus, Connaught Palace, New Delhi

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : Hotel Bercos Lounge (A unit of Dhaba Express), Shop No G-2/43 middle circus, Connaught Palace, New Delhi

2. Type of Occupancy : Resturant G Floors

3. Type of Case : RENEWAL

4. Details of previous NOC : F6/DFS/MS//2008/EH/141 dated 18-01-2008.

Fire Safety directives Letter No. : NA

Date of inspection : 24/10/2013

Name of the Inspecting Officer : Sh. M.K. Sharma (Assistant Divisional Officer)

Name and designation of Officer
from the building side : Mr. Rawat (Manager)

Year of Construction : 2007

10. Applicant's letter No. : letter No. F.22/11/Tsm/04/339/4-11 dated 06/01/2009

| S No | Minimum standards on fire prevention and fire safety U/R 33 | BBL Requirements | Provided at site (PSS Area) | Remarks MR/NMR (P.S.S Area) |
|------|---|------------------|-----------------------------|-----------------------------|
| 1. | Access of building | | | |
| | • Road width | NA | 4.5 mt | MR |
| | • Gate width | 1 Mt | 1.5 Mt | MR |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a.Number of staircases | 01 | P | MR |
| | • Upper floors | 01 | P | MR |
| | • Basements | 01 | P | MR |
| | b.Width of staircases | | | |
| | • Upper floors | 800 MM | 1000 MM | MR |
| | • Basements | 800 MM | 900 MM | MR |
| | c.Protection of exits | | | |
| | Fire check door | NA | NA | NA |
| | Pressurization | NA | NA | NA |
| | d.No of continuous staircase to terrace | 01 | P | MR |

mark

2/4

| | | | | |
|----|--|--|------------|----|
| | e.Width Of Corridor | 1250 | 2Mt | MR |
| | f.Door Size | | | |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4 | Smoke managements System | | | |
| | • Basements | 30 ACPH | Mechanical | MR |
| | • Upper floors | 12 ACPH | NATURAL | MR |
| 5 | Fire Extinguishers | | | |
| | • Total numbers | 06 | 08 | MR |
| | • Types | ABC,Co ₂ , Wco ₂ | P | MR |
| | • IS marking | YES | P | MR |
| 6 | First – Aid Hose Reels | | | |
| | • Total numbers on each floor | 01 | P | MR |
| | • Length of hose reel hose | 30 | P | MR |
| | • Nozzle diameter | 05 | P | MR |
| 7 | Automatic fire detection and alarming system | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8 | MOEFA | YES | P | MR |
| 9 | Public Address System | NA | NA | NA |
| 10 | Automatic Sprinkler System | | | |
| | • Basements | Yes | P | MR |
| | • Upper Floor | Yes | P | MR |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11 | Internal Hydrants | | | |

11/15

| | | | | |
|----|--|---------|---------|----|
| | <ul style="list-style-type: none"> • Size of riser/down- comer | NA | NA | NA |
| | <ul style="list-style-type: none"> • Number of hydrants per floor | NA | NA | NA |
| | <ul style="list-style-type: none"> • Hose Box | NA | NA | NA |
| 12 | Yard Hydrants | | | |
| | <ul style="list-style-type: none"> • Total number of hydrants | NA | NA | NA |
| | <ul style="list-style-type: none"> • Hose Box | NA | NA | NA |
| 13 | Pumping Arrangements | | | |
| | <ul style="list-style-type: none"> ○ Ground Level | NA | NA | NA |
| | <ul style="list-style-type: none"> • Discharge of main pump | NA | NA | NA |
| | <ul style="list-style-type: none"> • Head of main pump | NA | NA | NA |
| | <ul style="list-style-type: none"> • Number of main pumps | NA | NA | NA |
| | <ul style="list-style-type: none"> • Jockey pump out put | NA | NA | NA |
| | <ul style="list-style-type: none"> • Jockey pump head | NA | NA | NA |
| | <ul style="list-style-type: none"> • Standby Pump out put | NA | NA | NA |
| | <ul style="list-style-type: none"> • Standby Pump Head | NA | NA | NA |
| | <ul style="list-style-type: none"> • auto Staring/Manual stopping | NA | NA | NA |
| | <ul style="list-style-type: none"> • Pump House Access | NA | NA | NA |
| | <ul style="list-style-type: none"> ○ Terrace level | NA | NA | NA |
| | <ul style="list-style-type: none"> • Discharge of pump | NA | NA | NA |
| | <ul style="list-style-type: none"> • Head of the pump | 450 LPM | 450 LPM | MR |
| | <ul style="list-style-type: none"> • Power supply | 30 Mt | P | MR |
| | <ul style="list-style-type: none"> • Auto starting of pump | YES | P | MR |
| | | - | - | - |
| 14 | Captive water Storage for fire fighting | NA | NA | NA |
| | <ul style="list-style-type: none"> • Under ground tank capacity | NA | NA | NA |
| | <ul style="list-style-type: none"> • Draw of connection | NA | NA | NA |
| | <ul style="list-style-type: none"> • Fire service inlet | NA | NA | NA |
| | <ul style="list-style-type: none"> • Access to tank | YES | P | NA |
| | <ul style="list-style-type: none"> • Overhead Tank capacity | 5000 | P | MR |
| 15 | Exit Signage | YES | P | MR |
| 16 | Provision of Lifts | NA | NA | NA |
| | <ul style="list-style-type: none"> • Pressurization of Lift Shaft | NA | NA | NA |

Mar

N/6

| | | | | |
|----|---|-----|-----|----|
| | <ul style="list-style-type: none"> • Pressurization of lift lobby • Communication in lift Car • Fireman's Grounding Switch • Lift Signage | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 17 | Standby power supply | NR | P | MR |
| 18 | Refuge Area | | | |
| | <ul style="list-style-type: none"> • Total area | NA | NA | NA |
| | <ul style="list-style-type: none"> • Location | NA | NA | NA |
| 19 | Fire control room | | | |
| | <ul style="list-style-type: none"> • Detector system panel | NA | NA | NA |
| | <ul style="list-style-type: none"> • Flow Switch Panel | NA | NA | NA |
| | <ul style="list-style-type: none"> • PA System Panel | NA | NA | NA |
| | <ul style="list-style-type: none"> • Batter backup | NA | NA | NA |
| | <ul style="list-style-type: none"> • Building Floor Plans | NA | NA | NA |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any; | YES | ABC | MR |

The fire protection systems provided in the building were tested, checked and found non-functional at the time of inspection.

Keeping in view the non compliance of the minimum standards on Fire prevention and fire Safety required under the rules 35 of the Delhi fire service Rules 2010/ seating capacity 46 persons FSC is recommended.



D S Yadav
25-10-13

Signature of the Inspecting Officer

Name :- D S Yadav
Designation :- D.O. (CD)

submitted please
D S Yadav

M.K. Sharma
28/10/13

Signature of the Inspecting Officer

Name :- M.K. Sharma
Designation :- A. D.O. (CC)