

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DFS/MS/School/2013/W2/1182 Dated: 08/11/2013

FIRE SAFETY CERTIFICATE

Certified that the Happy Home Public School, Pkt-B-4, Sector-11, Rohini, Delhi-85 Comprised of Ground + Two Upper Floors and temporary shed on the terrace owned/occupied by Happy Home Public School has already been issued fire safety certificate vide letter no. F-6/DFS/MS/2006/43 dated 04/01/2006. The premises was re-inspected by the officer from this department on dated 19/10/2013 in the presence of Mrs Anita Hans and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have there fore deemed complied with the requirements of circular issued by Director of Education letter dated 17/01/2005 and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 08/11/2013 for a period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of Delhi Fire Service Rules, 2010.

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The temporary sheds on terrace shall not be used for class room purposes.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 08/11/13 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in



Copy to:

1. The Principal, Happy Home Public School, Pkt-B-4, Sector-11, Rohini, Delhi-85
2. The Director of Education, Old Secretariat, Delhi

G.F + Two upper Floors + Temporary Shed on the Terrace

INSPECTION REPORT

1. Name & address of the building: Happy Home Public School, Pocket-B-4, Sector 11
2. Type of Occupancy: Rohini, Delhi - Educational
3. Type of Case: New Case / Renewal
4. Details of previous NOC: F-6/MS/DPS/2006/113 dt 04-01-06
5. Fire Safety directives letter No: Circular of the director of Education
6. Date of inspection: 19-10-13
7. Name of the Inspecting Officers: N.P. SHARMA
8. Name and designation of officers from the building side: Mrs Anita Hans
9. Year of Construction: 2006
10. Applicant's letter No: H-H.P.S/13-14/216 dt 21-9-13

P.A. 4.515 m². CA 3167 m². No. S-1833 No. T-57 No. CR-42

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	P	MR
	• Upper Floors	03	03	MR
	• Basements	—	—	—
	b. Width of staircases	old case	old case	M.R. old case
	• Upper Floors	old case	old case	old case
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	1 mtr	1.6 mtr	MR
3	Compartmentation.			
	• Fire check door	—	—	—

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	—	—	—
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour	—	—
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	11 ISI marked	11 ABC type yes	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 m 5 mm	01 P P	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A		
8	MOEFA			
		N/A	P	N/A
9	Public Address System.			
		N/A	P	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	N/A		
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 mm one one	P P P	MR MR MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A		

13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pum 	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		450 LPM	P	MR
		40m	P	MR
		—	—	—
		—	—	—
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		5000 ltr	5000 ltr	MR
15	Exit Signage.	R	P	MR
16	Provision of Lifts.	NIA		MR
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
17	Standby power supply	—	—	—
18	Refuge Area.	NIA		
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 	—	—	—

	<ul style="list-style-type: none"> • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the ^(N)Inspecting Officer 19/10/13

Name N. P. SHARMA

Designation A. D. O.

Signature of the Inspecting Officer

Name

Designation