

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. f6/DFS/ms/school/2013/w2/1181

Dated: 08/11/2013

**FIRE SAFETY CERTIFICATE**

Certified that the M C Primary Co-ed School, U- Block Mangol Puri, Delhi- 110083 comprised of Ground + One Upper Floor owned/occupied by M C Primary School have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 26/10/2013 in the presence of Mrs. Padam Bagotra and that the building / premises is fit for occupancy of Educational building with effect from 08/11/2013 for a period of three years, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 6 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 08/11/13 at New Delhi

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
cfowz.dlfire@nic.in

Copy to:

1. The Principal, M C Primary Co-ed School, U- Block Mangol Puri, Delhi- 110083
2. The Addl. Director of Education, NMCD, Civic Centre, New Delhi.

*dca*

One Block - G F + one upper Floor

**INSPECTION REPORT**

1. Name & address of the building: M.C.Primary co-ed School, U-Block, Mangol Puri, Delhi-83
2. Type of Occupancy : Educational
3. Type of Case : New Case
4. Details of previous NOC : -
5. Fire Safety directives letter No : Circular of the Director of Education.....
6. Date of inspection : ...26/10/2013.....
7. Name of the Inspecting Officers: ...N. P. Sharma.....
8. Name and designation of officers  
From the building side : ...Mrs. Padam Bagotra (Principal).....
9. Year of Construction : ...1981.....
10. Applicant's letter No. : NIL 23/09/2013

PA 5212 sq. mtr., CA 773 sq.mtr., No. of Students 526, No. of Teachers-11, No. of Classrooms-16

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible	Accessible	M R
		----	----	----
		----	----	----
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	R	P	M R
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	Two	Two	M R
		----	----	----
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	1.5 mtr.	1.)1.7 mtrs. 2.)1.4 mtrs.	M R
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	----	----	----
		----	----	----
	e. No. of continuous staircases to terrace	----	----	----
		----	----	----

	g. Width of Corridor	----	----	----
	h. Door Size	1 mtr.	1.2 mtr.	MR ✓
3	<b>Compartmentation.</b>	N/A		
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	----	----	----
		----	----	----
		----	----	----
		----	----	----
4	<b>Smoke Management System.</b>	N/A		
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour		
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	5 ISI marked	5 ABC type Yes	MR ✓ MR ✓ MR ✓
6	<b>First-Aid Hose Reels.</b>	N/A		
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	30 m 5 mm	----	----
			----	----
			----	----
7	<b>Automatic fire detection and alarming system.</b>	N/A		
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	----	----	----
		----	----	----
		----	----	----
		----	----	----
8	<b>MOEFA</b>	N/A		
9	<b>Public Address System.</b>	----	----	----
10	<b>Automatic Sprinkler System.</b>	N/A		
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	----	----	----
		----	----	----
		----	----	----



	<ul style="list-style-type: none"> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	----	----	----
17	<b>Standby power supply</b>	N/A		
18	<b>Refuge Area:</b>	N/A		
	➤ Total Area	----	----	----
	➤ Location	----	----	----
19	<b>Fire Control Room</b>	N/A		
	• Detector System Panel	----	----	----
	• Flow Switch Panel	----	----	----
	• PA System Panel	----	----	----
	• Batter backup	----	----	----
	• Building Floor Plans	----	----	----
20	Special Fire Protection Systems for Protection of special Risks, if any:	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer *N. P. SHARMA* 29/10/13

Signature of the Inspecting Officer

Name *N. P. SHARMA*

Name

Designation *A D-O*

Designation

