

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DFS/MS/School/2013/W2/1180

Dated: 08 / 11 / 2013

FIRE SAFETY CERTIFICATE

Certified that the M C D Primary School, Block D-3, Sector – 16, Rohini, Delhi-110089 comprised of Ground Floor + One Upper Floor owned/occupied by M C D Primary School, have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 27/08/2013 in the presence of Sh. Rajbir Singh (Principal) and that the building / premises is fit for occupancy of Educational building with effect from 08 / 11 / 2013 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 The basement shall be used strictly as per the provision of building bye laws.
- 6 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 08 / 11 / 13 at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, M C D Primary School, Block D-3, Sector – 16, Rohini, Delhi-110089
2. The Addl. Director of Education, NMCD, Civic Centre, Delhi.

Two Nols of Blocker - both are GF + one upper floor

INSPECTION REPORT

1. Name & address of the building: MCD Primary School, Block D-3, Sector-16
2. Type of Occupancy: Rohini, Delhi-89
3. Type of Case: New Case / Renewal
4. Details of previous NOC: N/A
5. Fire Safety directives letter No: The circular of Director of Education
6. Date of inspection: 27-8-13
7. Name of the Inspecting Officers: N.P. SHARMA, ADO
8. Name and designation of officers from the building side: Sh. RAJ BIR SINGH, PRINCIPAL
9. Year of Construction: 2001
10. Applicant's letter No: - dt-02-4-13

PA-4150 m² C.A.-2875 m². Nols-1084, Nols T-26. Nols CR-33

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR ✓
	• Gate width	Accessible	Accessible	MR ✓
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	P	MR ✓
	• Upper Floors	Block 1 - 1	1	MR ✓
	• Basements	" - 2 - 1	1	MR ✓
	b. Width of staircases			
	• Upper Floors	Block 1 - 1.5 mts	2.2 mts	MR ✓
	• Basements	Block 2 - 1.5 mts	2 mts	MR ✓
	c. Protection of exits			
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size	1. mts	1.5 mts	MR ✓
3	Compartmentation.			
	• Fire check door	-	-	-

M/7

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	—	—	—
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour	—	—
		12 a/c per hour	—	—
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	10 ✓ ISI marked	11 ABC yes	MR MR MR
6	First-Aid Hose Reels. N/A			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m 5 mm	— — —	— — —
7	Automatic fire detection and alarming system. N/A			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	—	—	—
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System. N/A			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	—	—	—
11	Internal Hydrants N/A			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	—	—	—
12	Yard Hydrants. N/A			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	—	—	—

W18

13	Pumping Arrangements.	N/A		
	<ul style="list-style-type: none"> • Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pum 	-	-	-
14	Captive Water Storage for fire fighting.	N/A		
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	-	-	-
15	Exit Signage.	-	-	-
16	Provision of Lifts.	N/A		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	-
17	Standby power supply	-	-	-
18	Refuge Area.	N/A		
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	-	-	-
19	Fire Control Room	N/A		
	<ul style="list-style-type: none"> • Detector System Panel 	-	-	-

N/9

<ul style="list-style-type: none"> • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
20	Special Fire Protection Systems for Protection of special Risks, if any:	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer *R* 27-8-13

Name *N.P. SHARMA*

Designation *Asst. Div. offr.*

Signature of the Inspecting Officer

Name

Designation