

No. F.6/DFS/MS/EH/2013/SZ/ 1189

Dated: 11.11.2013

FIRE SAFETY CERTIFICATE

Certified that the Veda Restaurant at 307-308, DLF Plaza, Vasant Kunj, New Delhi running at second floor of the building comprised of two basement ground plus two upper floors was granted NOC by this department vide letter No. F6/DFS/MS/EH/2010/1362 dated 10.05.2013. The premises was re-inspected by the officer concerned of this department on 05.11.2013 in the presence of Mr. Ankit Kumar (Manager) of the restaurant and observed that fire safety norms as required under Rule 33 of Delhi Fire Service Rules, 2010 have deemed complied and that the building / premises is fit for occupancy class-D "Assembly building Restaurant" with effect from \_\_\_\_\_ for a period of Three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on ..... at New Delhi by



(Dr. G.C. Misra)  
Chief Fire Officer  
Delhi Fire Service  
Tel:- 011-23414333  
E-Mail:- cfhq.dfire@nic.in

Copy to: -

1. The DHO(South Zone), Office of Deputy Health Officer, M.C.D. Health Department South Zone, Green Park, New Delhi,
2. The Manager, Veda Restaurant at 307-308, DLF Plaza, Vasant Kunj, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The Basement shall be used strictly as per the provisions of Building Bye Laws.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

### INSPECTION REPORT

1	Name & address of the building	Veda Restaurant at 307-308, DLF Plaza, Vasant Kunj, New Delhi		
2	Type of Occupancy	Assembly building "D" Restaurant		
3	Type of case	Renewal		
4	Details of previous NOC	F6/MS/DFS/EH/2009/1362 dated 10.05.2013		
5	Fire safety directives letter No	Nil		
6	Date of inspection	05.11.2013		
7	Name of the inspecting Officers :	ADO D.B. Mukherjee		
8	Name and designation of officers from the building side	Sh. Ankit Kumar ( Manager),		
9	Year of construction	Nil	2 basement ground plus two upper floors.	
10	Applicant's letter No.	Nil	21.10.2013	(Resturant running at 2nd floor)
<b>S. NO.</b>	<b>Minimum Standards on fire prevention and fire safety U/R 33</b>	<b>NBC Requirement</b>	<b>Provided at site</b>	<b>Remarks MR / NMR</b>
<b>1</b>	<b>Access to building</b>			
	1) Road width	Required	10 Mtr Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	Two	2 Nos. Near Restaurant	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.5 Mtr	1.70 & 1.5 Mtr Provided	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to</b>	Required	Provided by Mall	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	Required	1.4, 1.66, 1.04 Provided	MR
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	Required	Provided by Mall	MR
	2. Sealing of electrical shafts	Required	Provided by Mall	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	basement	30 a/c per hour 12 a/c per hour	Mech. Ventilation Provided by Mall	MR
	upper floors		Mech. Ventilation Provided by Mall	MR
<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers		6 Nos	MR
	Types		ABC, Water Co2	MR
	ISI marking	ISI	Yes	MR



6	<b>First-Aid Hose Reels.</b>	<b>Provided &amp; Maintain by Mall</b>		
	total numbers on each floor	do	do	do
	Length of Hose reel hose	do	do	do
	Nozzle Diameter	do	do	do
7	<b>Automatic fire detection and alarming system:-</b>	<b>Provided &amp; Maintain by Mall</b>		
	Type of detectors	do	do	do
	location of Main Panel	do	do	do
	location of Repeater panel	do	do	do
	Alternate source of power	do	do	do
	hooter's location	do	do	do
8	<b>MOEFA</b>	<b>Provided &amp; Maintain by Mall</b>		
9	<b>Public Address System.</b>	<b>Provided &amp; Maintain by Mall</b>		
10	<b>Automatic Sprinkler System.</b>	<b>Provided &amp; Maintain by Mall</b>		
	basement	do	do	do
	upper floors	do	do	do
	sprinkler above false ceiling	do	do	do
11	<b>Internal Hydrants</b>	<b>Provided &amp; Maintain by Mall</b>		
	Size of riser/down-corner	do	do	do
	Number of Hydrants per floor	do	do	do
	hose Box	do	do	do
12	<b>Yard Hydrants.</b>	<b>Provided &amp; Maintain by Mall</b>		
	total number of hydrants	do	do	do
	hose box	do	do	do
13	<b>Pumping arrangements</b>	<b>Provided &amp; Maintain by Mall</b>		
	<b>1. Ground level</b>			
	a. Discharge of main Pump	do	do	do
	b. Head of main pump	do	do	do
	c. Number of main pumps	do	do	do
	d. jockey pump out put	do	do	do
	e. jockey pump head	do	do	do
	f. Standby Pump output	do	do	do
	g. Stanby Pump head	do	do	do
	h. Auto Starting/Manual stopping	do	do	do
	pump house access	do	do	do
	<b>2. Terrace level</b>	do	do	do
	a. Discharge of pump	do	do	do
	b. head of the pump	do	do	do
	c. Power supply	do	do	do
	d. Auto starting of pump	do	do	do
14	<b>Captive water storage for fire fighting</b>	<b>Provided &amp; Maintain by Mall</b>		
	1. Underground tank capacity	do	do	do
	a. Draw-off connection	do	do	do
	b. fire service inlet	do	do	do
	c. Access to tank	do	do	do
	Over head tank Capacity	do	do	do
15	<b>Exit Signage.</b>	do	do	do
16	<b>Provision of lifts.</b>	<b>Provided &amp; Maintain by Mall</b>		
	a. Pressurization of lift shaft	do	do	do
	b. pressurization of lift lobby	do	do	do
	c. communication in lift car	do	do	do
	d. Fireman's grounding switch	do	do	do
	e. Lift signage	do	do	do

17	Standby power supply	Provided & Maintain by Mall		
18	Refuge Area.	Provided & Maintain by Mall		
	total area	do	do	do
	location	do	do	do
19	Fire control room	Provided & Maintain by Mall		
	a. detector system Panel	do	do	do
	b. Flow switch Panel	do	do	do
	c. PA system Panel	do	do	do
	d. Batter backup	do	do	do
	e. Building floor plans	do	do	do
20	Special Fire Protection systems for protection of special risks, if any:			

The fire protection systems provided in the building were checked and found functional at the time of inspection.  
 Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010

Accordingly DFA is put up for your approval and signature please.

*[Handwritten Signature]*  
 8/11/2013

Signature of the inspecting officer  
 Name D.B. Mukherjee  
 Designation : ADO (BCP)

*DO (South)*

*[Handwritten Signature]*  
 8/11/13

*[Handwritten Signature]*  
 11/11/13

